



**RP - Sanjiv Goenka
Group**
Growing Legacies



Dhariwal Infrastructure Limited

CIN : U70109WB2006PLC111457
E-mail : dhariwalinfrastructure@rpsg.in

Ref. No.: DIL/HSE/F-09/22-23/78

Date: 23/11/2022

To,
The APCCF (C),
Ministry of Environment and Forest, Climate Change,
Regional Office (WCZ) Ground Floor;
East Wing, New Secretariat Building,
Civil Line, NAGPUR – 440001 (MH).

Sub.: Half Yearly Compliance Report of the Environmental Clearance for the period of 1st April 2022 to 30th September 2022.

Ref.: MoEF, Govt. of India Environmental Clearance No. J-13011/10/2009-IA. II (T) dated 4th December 2009.

Dear Sir,

We are operating 2 x 300 MW Thermal Power Plant M/s Dhariwal Infrastructure Limited at Plot No. C-6, MIDC, Tadali Industrial Area, Chandrapur (M.S.). We are enclosing herewith point wise compliance report of conditions stipulated in Environmental Clearance along with requisite annexures (In soft) granted vide above referred letter for the period of 1st April 2022 to 30th September 2022.

We are making our sincere efforts for creating cleaner and greener environment with-in and outside company premises.

Thanking you,

Yours faithfully,
For **DHARIWAL INFRASTRUCTURE LTD.**

Authorized Signatory

Encl.: As above

CC:

1. **The Member Secretary**, Central Pollution Control Board, Parivesh Bhawan, East Arjun Nagar, Delhi-110032.
2. **The Regional Director**, Central Pollution Control Board, Pune, Maharashtra.
3. **The Member Secretary**, Maharashtra Pollution Control Board, Kalpataru Point, 4th Floor, Sion (E'), Mumbai-400022.
4. **The Regional Officer**, Maharashtra Pollution Control Board, 1st Floor, Udyog Bhawan, Chandrapur-442401, Maharashtra.



**Environmental Compliance Report
for
the Period From
1st April 2022 to 30th September 2022**

Of

**M/s. DHARIWAL INFRASTRUCTURE LTD.
Plot No. C-6, C-7 & C-8,
Tadali Industrial Area,
MIDC, Village – Tadali,
Dist. - Chandrapur**

***Submitted to*
Ministry of Environment, Forest and Climate Change
Regional Office (WCZ), Ground Floor, East Wing
New Secretariat Building
Civil Line, Nagpur – 440001 (MH)**



1.0 PREAMBLE

Dhariwal Infrastructure Limited has been granted Environmental Clearance for 2 x 300 MW Thermal Power Plant vide MoEF&CC EC No. J-13011/10/2009-IA. II (T) dated 04-12-2009.

Unit -1 of Thermal Power Plant has been installed and commissioned in February 2014 and Unit -2 in August 2014. The MPCB Consent to Operate is valid up to 30.06.2024.

All the Environmental Protection & Conservation works including air pollution control systems, effluent treatment plant, sewage treatment plant, rain water harvesting, greenbelt development activities etc. are completed. The present compliance status is given below:

2.0 COMPLIANCE STATUS

The conditions stipulated in Environmental Clearance are followed scrupulously. Compliance is reported hereunder for the period from 1st April 2022 to 30th September 2022 in serial order of Environmental Clearance Letter as delineated below.

Sr. No.	Conditions	Compliance Status
(i)	No further expansion shall be permitted for this power plant in view of the uncertainty of water in lean season.	Noted.
(ii)	The two radial wells shall be constructed maintaining a distance of at least 450 m between them and at least 500 m from the nearest habitations/village boundary.	Complied, radial wells are constructed 500 meters away from the nearest habitation.
(iii)	Water from the radial well(s) shall be utilized only for extreme necessity during lean season and shall be kept only as standby arrangement during lean season.	Water from the radial well(s) is utilized only for extreme necessity during lean season and kept only as standby arrangement during lean season.
(iv)	Hydro-geological study of the area shall be reviewed annually and results submitted to the Ministry and concerned agency in the State Govt. In case adverse impact on ground water quantity and quality is observed, immediate mitigating steps to contain any adverse impact on ground water shall be undertaken.	Hydro-geological status of the area is reviewed regularly. Ground water level and Ground water quality in the study area is regularly analyzed. Reports for the compliance period (Aprl'22 to Sept'22) are enclosed as Annexure-1 .
(v)	A Two Bi-Flue stack of 275 m height shall be provided with continuous online monitoring equipment for SO _x , NO _x and PM. Exit velocity of flue gases shall not be less than 25 m/sec. Mercury emissions from stack shall also be monitored on periodic basis.	A Bi-Flue stack of 275 m height is provided with continuous online monitoring equipment for SO _x , NO _x and PM. Mercury emissions from stack are also being monitored on periodic basis. Report is enclosed as Annexure-2 .

(vi)	High Efficiency Electrostatic Precipitators (ESPs) shall be installed to ensure that particulate emission does not exceed 50 mg/Nm ³ .	High Efficiency Electrostatic Precipitator (ESP) for unit 1 & 2 are commissioned and in operation. Both ESP's are designed to ensure that particulate emission does not exceed 50 mg/Nm ³ . The analysis reports of stack emission monitoring for both units are enclosed as Annexure-2 .
(vii)	Adequate dust extraction system such as cyclones/ bag filters and water spray system in dusty areas such as in coal handling and ash handling points, transfer areas and other vulnerable dusty areas shall be provided.	Complied. Adequate dust extraction & dust suppression systems are provided in CHP & AHP. Water sprinklers & tanker sprinklers are administered as and when required.
(viii)	Utilization of 100% Fly Ash generated shall be made from 4 th year of operation of the plant. Status of implementation shall be reported to the Regional Office of the Ministry from time to time.	Complied, 100% Fly Ash generated is being taken by nearby cement plants and Brick Manufacturers for cement and Bricks manufacturing. Ash generation and utilization details for the period of Aprl'22 to Sept'22 are enclosed as Annexure-3 .
(ix)	Fly ash shall be collected in dry form and storage facility (silos) shall be provided. 100% fly ash utilization shall be ensured from 4 th year onwards, Unutilized fly ash shall be disposed off in the ash pond in the form of slurry form. Mercury and other heavy metals (As, Hg, Cr, Pb etc.) will be monitored in the bottom ash as also in the effluents emanating from the existing ash pond. No ash shall be disposed off in low lying area.	Complied, 02 no's of fly ash silo of 3280 MT capacity is constructed to handle dry ash. Mercury and other heavy metals are monitored in bottom ash and ash pond effluent. Condition for not using ash disposal in low lying area is omitted vide MoEF& CC (IA Division) Office Memorandum dated 28 August 2019. Heavy metal analysis report is enclosed as Annexure-4 .
(x)	Ash pond shall be lined with HDP/LDP lining or any other suitable impermeable media such that no leachate takes place at any point of time. Adequate safety measures shall also be implemented to protect the ash dyke from getting breached.	Complied, Ash pond is lined with LDP lining such that no leachate takes place at any point of time. Adequate safety measures like proper sloping, boulder pitching, greenbelt development, adequate bund thickness etc. are implemented to protect the ash dyke from getting breached.
(xi)	For disposal of Bottom Ash in abandoned mines (if proposed to be undertaken) it shall be ensured that the bottom and sides of the mined out areas are adequately lined with clay before Bottom Ash is filled up. The project proponent shall inform the State	Noted, will be complied.

	Pollution Control Board well in advance before undertaking the activity.	
(xii)	As per revised EC dated 09/09/2010 closed cycle cooling tower with Induced draft cooling towers shall be provided. The Effluents shall be treated as per the prescribed norms.	Closed cycle cooling system with Induced draft cooling towers is provided. The effluents are treated as per the prescribed norms and is utilized as per reduce, reuse and recycle techniques within the operating facility for example dust suppression, Bed Ash quenching, Ash Slurry water make-up purpose etc.
(xiii)	The treated effluents conforming to the prescribed standards only shall be discharged. Arrangements shall be made that effluents and storm water do not get mixed.	Our operating facility is based on ZLD (Zero liquid discharge). The treated effluents conforming to the prescribed standards are utilized as per reduce, reuse and recycle techniques within the operating facility. Arrangements are made such that effluents and storm water do not get mixed. Please refer Annexure-4 .
(xiv)	A sewage treatment plant shall be provided and the treated sewage shall be used for raising greenbelt/plantation.	Complied, Sewage treatment plant of adequate capacity is provided and the treated sewage is used for raising greenbelt/plantation.
(xv)	Rainwater harvesting should be adopted Central Groundwater Authority/ Board shall be consulted for finalization of appropriate rainwater harvesting technology within a period of three months from the date of clearance and details shall be furnished.	Rain water harvesting pond is developed in which, rain water is regularly collected through natural drains. We have permission from Central Ground Water Board for implementation of rain water harvesting.
(xvi)	Adequate safety measures shall be provided in the plant area to check/minimize spontaneous fires in coal yard, especially during summer season. Copy of these measures with full details along with location plant layout shall be submitted to the Ministry as well as to the Regional Office of the Ministry.	Provision of Adequate safety measures in the plant area to check/minimize spontaneous fires in coal yard is provided. Dedicated fire hydrant system comprised of fire monitors and rain guns have been provided around coal stock yard.
(xvii)	Storage facilities for auxiliary liquid fuel such as LDO and/ HFO/LSHS shall be made in the plant area in consultation with Department of Explosives, Nagpur. Sulphur content in the liquid fuel will not exceed 0.5%. Disaster Management Plan shall be prepared to meet any eventuality in case of an accident taking place due to	Complied, License from DoE for storage facility of auxiliary liquids is granted, Sulphur content is maintained within the permissible range of 0.5%. Disaster Management Plan is prepared and in place and approved by appropriate authority. DoE license is enclosed as Annexure-5 .

	storage of oil.	
(xviii)	Regular monitoring of ground water level shall be carried out by establishing a network of existing wells and constructing new piezometers. Monitoring around the ash pond area shall be carried out particularly for heavy metals (Hg, Cr, As, Pb) and records maintained and submitted to the Regional Office of this Ministry. The data so obtained should be compared with the baseline data so as to ensure that the ground water quality is not adversely affected due to the project.	We are monitoring Ground water level and Quality inside industry premises and nearby ash pond area periodically. Reports are enclosed as Annexure-1 .
(xix)	Green Belt consisting of 3 tiers of plantations of native species around plant and at least 100 m width shall be raised. Wherever 100 m width is not feasible a 50 m width shall be raised and adequate justification shall be submitted to the Ministry. Tree density shall not less than 2500 per ha with survival rate not less than 70 %.	As on date about 1,63,668 trees have been planted with a survival rate of not less than 70%. The major existing trees are Akeshiya, Imli, Karanj, Mahaneem, Neem, Nilgiri, Peltocofora, Sisam and Casia, casurina, Eucalyptus etc. The other existing trees are Aapta, Amla, Anjeer, Areka Palm, Aerial Palm, Arjun ,Ashoka, Bargad, Badam, Banana, Boganvel, Chikku, Coconut, Flower tree, Ficus benjamina, Goldan Bambu, Green Bambu, Gulmohar, Jambhul Jaswant, Kadam, Kanher ,Kawat, Mahagani, Mango, Mogra Mosambi, Nimbu , Pipal, Rain Tree, Red Rose, Royal Palm, Ornamental Plants, Saru, Simal, Spindal Palm, Silver oke , Swastik, Vel (Kourav & Pandava), Vidya, X-mas tree, Yellow Bell, Bakul, Papaya, Sitaphal, Bel, Shahtut ,Anar, Sevga, Amrud,Ber, Kher etc. (Photographs attached as Annexure-6).
(xx)	First Aid and sanitation arrangements shall be made for the drivers and other contract workers during construction phase.	Complied during construction phase.
(xxi)	Noise level emanating from turbines shall be so controlled such that the noise in the work zone shall be limited to 75 dB(A). For people working in the high noise area, requisite personal protective equipment like earplugs/ear muffs etc.	We are regularly monitoring work place noise level at 25 locations including turbine, air compressors on quarterly basis. Norms for Work zone Noise level is 85 dB(A) and for ambient noise level, it is 75 dB(A). The results are well

	<p>shall be provided. Workers engaged in noisy areas such as turbine area, air compressors etc. shall be periodically examined to maintain audiometric record and for treatment of any hearing loss including shifting to non noisy/less noisy areas.</p>	<p>within the limit.</p> <p>Noise level emanating from turbines is controlled such that the noise in the work zone is well within limit. For people working in the high noise area, requisite personal protective equipment like earplugs/ear muffs etc. are provided. Workers engaged in noisy areas are periodically examined & we are maintaining audiometric record and for treatment for any hearing loss including shifting to suitable areas is done. The work zone noise results are enclosed herewith as Annexure-7(A) & 7(B).</p>
(xxii)	<p>Regular monitoring of ground level concentration of SO₂, NO_x, RSPM (PM₁₀/PM_{2.5}) and Hg shall be carried out in the impact zone and records maintained. If at any stage these levels are found to exceed the prescribed limits, necessary control measures shall be provided immediately. The location of the monitoring stations and frequency of monitoring shall be decided in consultation with SPCB. Periodic reports shall be submitted to the Regional Office of the Ministry. The data shall also be put on the website of the company.</p>	<p>Complied, regular ambient air quality monitoring from NABL accredited laboratory at six locations is carried out and reports for the compliance period are enclosed as Annexure-8 and being submitted regularly.</p>
(xxiii)	<p>A good action plan for R&R (if applicable) with package for the project affected persons be submitted and implemented as per prevalent R&R policy within three months from the date of issue of this letter.</p>	<p>We are located in Maharashtra Industrial Development Corporation (MIDC) area, hence R & R is not applicable to us.</p>
(xxiv)	<p>An amount of Rs. 12.0 Crores shall be earmarked as one time capital cost for CSR programme. Subsequently a recurring expenditure of Rs. 3.0 Crore per annum shall be earmarked as recurring expenditure for CSR activities. Details of the activities to be undertaken shall be submitted within month along with road map for implementation.</p>	<p>Road map is worked out for implementation of CSR activities. A partnership along with Zila Parishad, Chandrapur, and local NGO's for improving health, sanitation, education, women empowerment, skill development, agriculture, rural development in ten Gram panchayat is done and further work is under progress. The implementation of following CSR activities undertaken in the aforesaid period.</p>

		<ol style="list-style-type: none"> 1. Training on Health & Sanitation in nearby nine villages. Supply of Sanitary amenities to the locals. 2. Swachh Bharat Abhiyan in nine villages. 3. Construction of toilets and hand wash facilities. 4. Training to Adolescent girls. 5. Training to villagers of nine villages for Digital empowerment.. 6. Agriculture Projects in nearby villages. 7. Educational Programs in nearby villages. 8. Training to SHG's (Self Help Groups) for self-employment. 9. Skill development training for youth is being imparted regularly. <p>Details of CSR activities are attached as Annexure-9.</p>
(xxv)	<p>As part of CSR programme the company shall conduct need based assessment for the nearby villages to study economic measures with action plan which can help in upliftment of poor section of society. Income generating projects consistent with the traditional skills of the people besides development of fodder farm, fruit bearing orchards, vocational training etc. can form a part of such programme. Company shall provide separate budget for community development activities and income generating programs. This will be in addition to vocational training for individuals imparted to take up self employment and jobs.</p>	<p>A need based survey had been carried out by Social Action for Rural Development (SARDA) in nearby areas to assess the social and economic status of the people based on which a comprehensive document is prepared to deal with need based CSR activities. The implementation of following CSR activities undertaken in the aforesaid period.</p> <ol style="list-style-type: none"> 1. Training on Health & Sanitation in nearby nine villages. Supply of Sanitary amenities to the locals. 2. Swachh Bharat Abhiyan in nine villages. 3. Construction of toilets and hand wash facilities. 4. Training to Adolescent girls. 5. Training to villagers of nine villages for Digital empowerment.. 6. Agriculture Projects in nearby villages. 7. Educational Programs in nearby

		<p>villages.</p> <p>8. Training to SHG's (Self Help Groups) for self-employment.</p> <p>9. Skill development training for youth is being imparted regularly.</p> <p>Details of CSR activities are attached as Annexure-9.</p>
(xxvi)	Provision shall be made for the housing of construction labors within the site with all necessary infrastructure and facilities such as fuel for cooking, mobile toilets, mobile STP, safe drinking water, medical health care, crèche etc. The housing may be in this form of temporary structures to be removed after the completion of the project.	Complied during construction phase. Demolition of temporary structures of construction phase is under progress.
(xxvii)	The project proponent shall advertise in at least two local newspapers widely circulated in the region around the project, one of which shall be in the vernacular language of the locality concerned within seven days from the date of this clearance letter, informing that the project has been accorded environmental clearance and copies of clearance letter are available with the State Pollution Control Board/ Committee and may also be seen at Website of the Ministry of Environment and Forests at http://envfor.nic.in .	Complied.
(xxviii)	A copy of the clearance letter shall be sent by the proponent to concerned Panchayat, Zila Parisad / Municipal Corporation, urban local body and the local NGO, if any, from whom suggestions/representations, if any, received while processing the proposal. The clearance letter shall also be put on the website of the Company by the proponent.	Complied. Copy of DIL Environment Clearance is put in the company website. www.dilenergy.co.in
(xxix)	A separate Environment Management Cell with qualified staff shall be set up for implementation of the stipulated environmental safeguards.	Complied. Environment Management Cell with qualified staff is set up for implementation & maintaining the stipulated environmental safeguards.
(xxx)	The proponent shall upload the status of compliance of the stipulated EC conditions, including results of	Complied. Status of compliance is being uploaded on company's website,

	monitored data on their website and shall update the same periodically. It shall simultaneously be sent to the Regional Office of MoEF, the respective Zonal Office of CPCB and the SPCB. The criteria pollutant levels namely; SPM, RSPM (PM ₁₀ /PM _{2.5}) SO ₂ NO _x (ambient levels as well as stack emissions) shall be displayed at a convenient location near the main gate of the company in the public domain.	www.dilenergy.co.in EC compliance reports are being sent to designated Regulatory Bodies regularly. Criteria pollutant levels are displayed at the main gate of the company for the general public.
(xxxii)	The project proponent shall also submit six monthly reports on the status of compliance of the stipulated EC conditions including results of monitored data (both in hard copies as well by e-mail) to the respective Regional Office of MoEF, the respective Zonal Office of CPCB and the SPCB.	Yes, six monthly reports are regularly submitted since beginning, about the status of compliance of the stipulated EC conditions including results of monitored data to the respective Regional office of MoEF&CC, the respective Zonal office of CPCB and the SPCB.
(xxxiii)	The environment statement for each financial /year ending 31 st March in Form-V as is mandated to be submitted by the project proponent to the concerned State Pollution Control Board as prescribed under the Environment (Protection) Rules, 1986, as amended subsequently, shall also be put on the website of the company along with the status of compliance of EC conditions and shall also be sent to the respective Regional Offices of the Ministry by e-mail.	Yes, Environment Statement in Form-V for financial year ending 31 st March 2022 is submitted to MPCB. Acknowledged letter copy is enclosed herewith as Annexure -10 . Copy of the same has been uploaded on company's website, i.e. www.dilenergy.co.in .
(xxxiii)	The project proponent shall submit six monthly reports on the status of the implementation of the stipulated environmental safeguards to the Ministry of Environment and Forests, its Regional Office, Central Pollution Control Board and State Pollution Control Board. The project proponent shall upload the status of compliance of the environment of the environmental clearance conditions on their website and update the same periodically and simultaneously send the same by e-mail to the Regional Office, Ministry of Environment and Forests.	Complied, six monthly reports are regularly submitted about the status of the implementation of the stipulated environmental safeguards to the Ministry of Environment and Forests Regional office, Central Pollution Control Board and State Pollution Control Board. Copy of the same has been uploaded on company's website, i.e. www.dilenergy.co.in .
(xxxiv)	Regional Office of the Ministry of	Being Complied, Compliance status has

	Environment & Forests will monitor the implementation of the stipulated conditions. A complete set of documents including Environmental Impact Assessment Report and Environment Management Plan along with the additional information submitted from time to time shall be forwarded to the Regional Office for their use during monitoring. Project proponent will upload the compliance status in their website and up-date the same from time to time at least six monthly basis. Criteria pollutants levels including NOx (from stack & ambient air) shall be displayed at the main gate of the power plant.	been uploaded on company's website, www.dilenergy.co.in . Criteria pollutant levels are displayed at the main gate of the company.
(xxxv)	Separate funds shall be allocated for implementation of environmental protection measures along with item-wise break-up. These cost shall be included as part of the project cost. The funds earmarked for the environment protection measures shall not be diverted for other purposes and year-wise expenditure should be reported to the Ministry.	Yes, separate funds are allocated for implementation of environmental protection measures. Total Expenses from 1 st April 2022 to 30 th September 2022 were 255.97 Lakhs on environment control measures.
(xxxvi)	The project authorities shall inform the Regional Office as well as the Ministry regarding the date of financial closure and final approval of the project by the concerned authorities and the dates of start of land development work and commissioning of plant.	Plant is in operation. COD for unit #1 was 11 th Feb. 2014 & for unit #2 was 2 nd Aug. 2014. Information has been given to the authorities.
	Full cooperation shall be extended to the Scientists/Officers from the Ministry/Regional Office of the Ministry at Bhopal/CPCB/SPCB who would be monitoring the compliance of environmental status.	Noted & Agreed.

SL No	Additional Conditions (as per MoEF & CC Notification No. S.O. 1561(E), dated 21.05.2020)	Compliance Status
(1)	Setting Up Technology Solution for emission norms:	
	(i) Compliance of specified emission	ESP's are designed to ensure that

	norms for Particulate Matter, as per extant notifications and instructions of Central Pollution Control Board, issued from time to time.	particulate emission does not exceed 50 mg/Nm ³ .
	(ii) In case of washries, Middling and rejects to be utilized in FBC (Fluidized Bed Combustion) technology based thermal power plants. Washery to have linkage for middling and rejects in Fluidized Bed Combustion plants.	Not Applicable to us.
(2)		
	(i) The thermal powers plants shall comply with conditions, as notified in the Fly Ash notification issued from time to time, without being entitled to additional capacity of fly ash pond (for existing power generation capacity) on ground of switching from washed coal to unwashed coal.	Plant management is focused on effective utilization of Ash generated at site. For achieving 100% dry Ash utilization, Ash generated is being utilized in nearby cement plants and Brick Manufacturers and others value added products.
	(ii) Appropriate Technology solutions shall be applied to optimize water consumption for Ash management;	<ul style="list-style-type: none"> •Entire Ash is handled in dry form without requiring water except furnace Ash •Furnace Ash or Bottom Ash is transported as slurry from bottom Ash hopper to the Ash pond. After the process of decantation, water is recycled and reused again in transportation of Ash slurry.
	(iii) The segregation of ash may be done at the Electro-Static Precipitator stage, if required, based on site specific conditions, to ensure maximum utilization of fly ash;	High efficiency ESPs have been installed and entire quantity of Ash collected from ESP's is utilized as per available regulatory guideline.
	(iv) Subject to 2(i) above, the thermal power plants to dispose fly ash in abandoned or working mines (to be facilitated by mine owner) with environmental safeguards.	Noted, will be complied.
(3)	Transportation:	
	(i) Coal transportation may be undertaken by covered Railway wagon (railway wagons covered by tarpaulin or other means) and/or covered conveyer beyond the mine area. However, till such time enabling Rail transport/conveyer infrastructure is not available, road transportation may be undertaken in trucks, covered by tarpaulin or other	<p>Coal transportation is being done through Rail.</p> <p>However, transportation of coal by road is carried out by covered truck only as and when needed.</p>

	means.	
	<p>(ii) It shall be ensured by the thermal power plant that</p> <p>a. Rail siding facility or conveyor facility is set up at or near the power plant, for transportation by rail or conveyor; and</p> <p>b. If transportation by rail or conveyor facility is not available, ensure that the coal is transported out from the Delivery Point of the respective mine in covered trucks (by tarpaulin or other means), or any mechanized closed trucks by road.</p>	<p>There is a railway siding facility within the plant premises.</p> <p>Noted, Being complied</p>

Annexure – 1

GROUND WATER LEVEL & QUALITY STATUS

April-2022

Sr. No. of Villages	Village Name	Details of Locations	Field Code No.	Date of Measurement	Water Level below ground level (level in mbmp - magl = mbgl)
1.	Village- Pandharkwada	Dugwell of Shri PandariZitrajiWadai Farm	DIL 1	11/04/2022	7.65
2.	Village- Sonegaon	Gram Panchayat Dugwell, Near Hanuman Mandir	DIL 2	11/04/2022	7.90
3.	Village- Yerur	Dugwell of ShriRavindraPandurangji Balki	DIL 3	11/04/2022	8.28
4.	Village- Wandhari	Borewell Water of Hanuman Mandir	DIL 4	11/04/2022	8.76
5.	Village- Ghodpeth	Dugwell of Shiv Mandir	DIL 5	11/04/2022	2.35
6.	Village- Tadali	GrampanchayatDugwell Near Z.P.Primary School	DIL 6	11/04/2022	1.69
7.	Village- Morwa	Dugwell near Jagnath Baba Mandir	DIL 7	11/04/2022	2.32
8.	Village- Wadha	Intake Well	DIL 8	12/04/2022	9.73
9.	MIDC,Tadali	Near Recovery Pump House-I, PZ-1	DIL 9	12/04/2022	4.54
10.	MIDC,Tadali	Near Recovery Pump House-II, PZ-2	DIL 10	12/04/2022	2.29
11.	MIDC,Tadali	Ash Pond II, PZ-3	DIL 11	12/04/2022	7.35
12.	MIDC,Tadali	Near Railway Crossing of WB-2, PZ-4	DIL 12	12/04/2022	2.46
13.	MIDC,Tadali	Near ETP Security Post, PZ-5	DIL 13	12/04/2022	2.27
14.	MIDC,Tadali	Near AAQMS Cabin-3, PZ-6	DIL 14	12/04/2022	3.65
15.	Village- Sakharwahi	Dugwell Water from ShriRavindraBhagwat Farm	DIL 15	12/04/2022	5.74
Note: All the above Ground Water Level Analysis were done by MOEF Approved 3 rd party M/s Vardan EnviroLab					

July-2022

Sr. No. of Villages	Village Name	Details of Locations	Field Code No.	Date of Measurement	Water Level below ground level (level in mbmp - magl = mbgl)
1.	Village- Pandharkwada	Dugwell of Shri PandariZitrajiWadai Farm	DIL 1	21/07/2022	5.65
2.	Village- Sonegaon	Gram Panchayat Dugwell,Near Hanuman Mandir	DIL 2	21/07/2022	5.89
3.	Village- Yerur	Dugwell of ShriRavindraPandurangji Balki	DIL 3	21/07/2022	6.32
4.	Village- Wandhari	Borewell Water of Hanuman Mandir	DIL 4	21/07/2022	5.25
5.	Village- Ghodpeth	Dugwell of Shiv Mandir	DIL 5	21/07/2022	1.45
6.	Village- Tadali	GrampanchayatDugwell Near Z.P.Primary School	DIL 6	21/07/2022	1.25
7.	Village- Morwa	Dugwell near Jagnath Baba Mandir	DIL 7	21/07/2022	1.90
8.	Village- Wadha	Intake Well	DIL 8	21/07/2022	4.69
9.	MIDC,Tadali	Near Recovery Pump House-I, PZ-1	DIL 9	21/07/2022	2.61
10.	MIDC,Tadali	Near Recovery Pump House-II, PZ-2	DIL 10	21/07/2022	1.11
11.	MIDC,Tadali	Ash Pond II, PZ-3	DIL 11	21/07/2022	3.56
12.	MIDC,Tadali	Near Railway Crossing of WB-2, PZ-4	DIL 12	21/07/2022	1.27
13.	MIDC,Tadali	Near ETP Security Post, PZ-5	DIL 13	21/07/2022	1.35
14.	MIDC,Tadali	Near AAQMS Cabin-3, PZ-6	DIL 14	21/07/2022	2.06
15.	Village- Sakharwahi	Dugwell Water from ShriRavindraBhagwat Farm	DIL 15	21/07/2022	2.56
Note: All the above Ground Water Level Analysis were done by MOEF Approved 3 rd party M/s Vardan EnviroLab					

Sr. No.	Parameters	Acceptable / Permissible Limit (IS 10500: 2012)	Concentration			
			Location			
			Dugwell Water, Village-Pandharkawda)	Borewell Water, Village-Sonegaon)	Dugwell Water, Village-Yerur)	Borewell Water, Village-Wandhri
			11-04-2022	11-04-2022	11-04-2022	11-04-2022
1.	pH value	6.5 to 8.5	7.26	7.64	7.29	7.48
2.	Colour, Hazen units	5/15	*BDL(**DL 1)	*BDL(**DL 1)	*BDL(**DL 1)	*BDL(**DL 1)
3.	Turbidity, NTU	1/5	*BDL(**DL 1 NTU)	*BDL(**DL 1 NTU)	*BDL(**DL 1 NTU)	*BDL(**DL 1 NTU)
4.	Odour	--	Agreeable	Agreeable	Agreeable	Agreeable
5.	Total Hardness(as CaCO ₃) mg/l	300/600	271.32	183.60	136.68	291.72
6.	Calcium (as Ca) ,mg/l	75/200	76.04	48.24	46.61	89.12
7.	Total Alkalinity (as CaCO ₃)mg/l	200/600	210.12	195.84	189.72	181.56
8.	Chloride (as Cl), mg/l	250/1000	141.45	39.60	38.66	78.27
9.	Free Residual Chlorine, mg/l	0.2/1.0	*BDL(**DL 0.15mg/l)	*BDL(**DL 0.15mg/l)	*BDL(**DL 0.15mg/l)	*BDL(**DL 0.15mg/l)
10.	Magnesium (as Mg), mg/l	30/100	19.74	15.31	4.90	16.75
11.	Total dissolved solids, mg/l	500/2000	860.0	620.0	520.0	710
12.	Sulphate (as SO ₄), mg/l	200/400	86.86	56.86	54.43	11.57
13.	Fluoride (as F), mg/l	1.0/1.5	1.08	0.94	0.90	1.02
14.	Iron (as Fe), mg/l	1.0	BDL(*DL 0.01 mg/l)	BDL(*DL 0.01 mg/l)	BDL(*DL 0.01 mg/l)	BDL(*DL 0.01 mg/l)
15.	Boron (as B) mg/l	0.5/1.0	*BDL(*DL 0.01 mg/l)	*BDL(*DL 0.01 mg/l)	*BDL(*DL 0.01 mg/l)	*BDL(*DL 0.01 mg/l)
16.	Total Chromium (as Cr) mg/l	0.05	*BDL(*DL 0.002 mg/l)	*BDL(*DL 0.002 mg/l)	*BDL(*DL 0.002 mg/l)	*BDL(*DL 0.002 mg/l)
17.	Zinc (as Zn) mg/l	5/15	7.26	BDL(*DL 0.01 mg/l)	BDL(*DL 0.01 mg/l)	BDL(*DL 0.01 mg/l)
18.	Copper (as Cu), mg/l	0.05/1.5	*BDL(**DL 1)	* BDL(**DL 0.002 mg/l)	* BDL(**DL 0.002 mg/l)	* BDL(**DL 0.002 mg/l)
19.	Manganese (as Mn), mg/l	0.1/0.3	*BDL(**DL 0.01 mg/l)	*BDL(**DL 0.01 mg/l)	*BDL(**DL 0.01 mg/l)	*BDL(**DL 0.01 mg/l)
20.	Cadmium as Cd, mg/l	0.003	*BDL(**DL 0.002 mg/l)	*BDL(**DL 0.002 mg/l)	*BDL(**DL 0.002 mg/l)	*BDL(**DL 0.002 mg/l)
21.	Lead (as Pb) mg/l	0.01	*BDL(**DL 0.002 mg/l)	*BDL(**DL 0.002 mg/l)	*BDL(**DL 0.002 mg/l)	*BDL(**DL 0.002 mg/l)

22.	Selenium as Se	0.01	*BDL(**DL 0.001 mg/l)	*BDL(**DL 0.001 mg/l)	*BDL(**DL 0.001 mg/l)	*BDL(**DL 0.001 mg/l)
23.	Total Arsenic (as As) mg/l	0.01/0.05	*BDL(**DL 0.002 mg/l)	*BDL(**DL 0.002 mg/l)	*BDL(**DL 0.002 mg/l)	*BDL(**DL 0.002 mg/l)
24.	Mercury (as Hg) mg/l	0.001	*BDL (**DL 0.0005 mg/l)	*BDL (**DL 0.0005 mg/l)	*BDL (**DL 0.0005 mg/l)	*BDL (**DL 0.0005 mg/l)

Note: 1) All the above Ground Water Quality Analysis were done by MOEF Approved 3rd party M/s Vardan EnviroLab

2) Information given to local panchayat through DIL CSR team for the necessary treatment & assistance.

Sr. No.	Parameters	Acceptable / Permissible Limit (IS 10500: 2012)	Concentration			
			Location			
			Dugwell Water, Village-Morwa)	Dugwell Water, Village – Ghodpeth)	Dugwell Water, Village – Tadali)	Ground Water from Intake Well near Wadha Village
			11-04-2022	11-04-2022	11-04-2022	11-04-2022
1.	pH value	6.5 to 8.5	7.66	7.46	7.71	7.74
2.	Colour, Hazen units	5/15	*BDL(**DL 1)	*BDL(**DL 1)	*BDL(**DL 1)	*BDL(**DL 1)
3.	Turbidity, NTU	1/5	*BDL(**DL 1 NTU)	*BDL(**DL 1 NTU)	*BDL(**DL 1 NTU)	*BDL(**DL 1 NTU)
4.	Odour	--	Agreeable	Agreeable	Agreeable	Agreeable
5.	Total Hardness(as CaCO ₃) mg/l	300/600	267.24	261.12	263.16	124.44
6.	Calcium (as Ca) ,mg/l	75/200	77.68	68.68	86.67	39.25
7.	Total Alkalinity (as CaCO ₃)mg/l	200/600	189.72	183.60	189.72	116.28
8.	Chloride (as Cl), mg/l	250/1000	196.14	29.23	97.13	38.19
9.	Free Residual Chlorine, mg/l	0.2/1.0	*BDL(**DL 0.15mg/l)	*BDL(**DL 0.15mg/l)	*BDL(**DL 0.15mg/l)	*BDL(**DL 0.15mg/l)
10.	Magnesium (as Mg), mg/l	30/100	17.75	21.73	11.30	6.40
11.	Total dissolved solids, mg/l	500/2000	784.0	580.0	810.0	830.0
12.	Sulphate (as SO ₄), mg/l	200/400	76.72	58.15	66.01	36.86
13.	Fluoride (as F), mg/l	1.0/1.5	0.48	0.65	0.78	BDL(*DL 0.2 mg/l)
14.	Iron (as Fe), mg/l	1.0	0.22	BDL(*DL 0.01 mg/l)	BDL(*DL 0.01 mg/l)	BDL(*DL 0.01 mg/l)
15.	Boron (as B) mg/l	0.5/1.0	*BDL(*DL 0.01 mg/l)	*BDL(*DL 0.01 mg/l)	*BDL(*DL 0.01 mg/l)	*BDL(*DL 0.01 mg/l)
16.	Total Chromium (as Cr) mg/l	0.05	*BDL(*DL 0.002 mg/l)	*BDL(*DL 0.002 mg/l)	*BDL(*DL 0.002 mg/l)	*BDL(*DL 0.002 mg/l)
17.	Zinc (as Zn) mg/l	5/15	0.23	BDL(*DL 0.01 mg/l)	BDL(*DL 0.01 mg/l)	BDL(*DL 0.01 mg/l)
18.	Copper (as Cu), mg/l	0.05/1.5	* BDL(**DL 0.002 mg/l)	* BDL(**DL 0.002 mg/l)	* BDL(**DL 0.002 mg/l)	* BDL(**DL 0.002 mg/l)
19.	Manganese (as Mn), mg/l	0.1/0.3	*BDL(**DL 0.01 mg/l)	*BDL(**DL 0.01 mg/l)	*BDL(**DL 0.01 mg/l)	*BDL(**DL 0.01 mg/l)
20.	Cadmium as Cd, mg/l	0.003	*BDL(**DL 0.002 mg/l)	*BDL(**DL 0.002 mg/l)	*BDL(**DL 0.002 mg/l)	*BDL(**DL 0.002 mg/l)
21.	Lead (as Pb) mg/l	0.01	*BDL(**DL 0.002 mg/l)	*BDL(**DL 0.002 mg/l)	*BDL(**DL 0.002 mg/l)	*BDL(**DL 0.002 mg/l)
22.	Selenium as Se	0.01	*BDL(**DL 0.001 mg/l)	*BDL(**DL 0.001 mg/l)	*BDL(**DL 0.001 mg/l)	*BDL(**DL 0.001 mg/l)

Sr. No.	Parameters	Acceptable / Permissible Limit (IS 10500: 2012)	Concentration			
			Location			
			Near Recovery Pump House-I,(Ash Pond) PZ-1	Near Recovery Pump House-II,(Ash Bund) PZ-2	Ash Pond II, PZ-3	Near Railway Crossing of WB-2, PZ-4
			11-04-2022	11-04-2022	11-04-2022	11-04-2022
1.	pH value	6.5 to 8.5	7.18	7.56	7.66	7.69
2.	Colour, Hazen units	5/15	1	1	*BDL(**DL 1)	1
3.	Turbidity, NTU	1/5	2	2	*BDL(**DL 1 NTU)	2
4.	Odour	--	Agreeable	Agreeable	Agreeable	Agreeable
5.	Total Hardness(as CaCO ₃) mg/l	300/600	199.92	210.12	169.32	210.12
6.	Calcium (as Ca) ,mg/l	75/200	48.24	58.05	45.79	50.69
7.	Total Alkalinity (as CaCO ₃)mg/l	200/600	150.96	153.0	150.96	173.40
8.	Chloride (as Cl), mg/l	250/1000	36.78	53.75	140.50	53.75
9.	Free Residual Chlorine, mg/l	0.2/1.0	*BDL(**DL 0.15mg/l)	*BDL(**DL 0.15mg/l)	*BDL(**DL 0.15mg/l)	*BDL(**DL 0.15mg/l)
10.	Magnesium (as Mg), mg/l	30/100	19.27	15.79	13.33	20.26
11.	Total dissolved solids, mg/l	500/2000	440.0	452.0	410.0	495.0
12.	Sulphate (as SO ₄), mg/l	200/400	54.58	58.29	59.43	63.01
13.	Fluoride (as F), mg/l	1.0/1.5	0.51	0.29	0.30	0.45
14.	Iron (as Fe), mg/l	1.0	BDL(*DL 0.01 mg/l)	BDL(*DL 0.01 mg/l)	BDL(*DL 0.01 mg/l)	BDL(*DL 0.01 mg/l)
15.	Boron (as B) mg/l	0.5/1.0	*BDL(*DL 0.01 mg/l)	*BDL(*DL 0.01 mg/l)	*BDL(*DL 0.01 mg/l)	*BDL(*DL 0.01 mg/l)
16.	Total Chromium (as Cr) mg/l	0.05	*BDL(*DL 0.002 mg/l)	*BDL(*DL 0.002 mg/l)	*BDL(*DL 0.002 mg/l)	*BDL(*DL 0.002 mg/l)
17.	Zinc (as Zn) mg/l	5/15	BDL(*DL 0.01 mg/l)	BDL(*DL 0.01 mg/l)	BDL(*DL 0.01 mg/l)	BDL(*DL 0.01 mg/l)
18.	Copper (as Cu), mg/l	0.05/1.5	*BDL(**DL 0.002 mg/l)	*BDL(**DL 0.002 mg/l)	*BDL(**DL 0.002 mg/l)	*BDL(**DL 0.002 mg/l)
19.	Manganese (as Mn), mg/l	0.1/0.3	*BDL(**DL 0.01 mg/l)	*BDL(**DL 0.01 mg/l)	*BDL(**DL 0.01 mg/l)	*BDL(**DL 0.01 mg/l)
20.	Cadmium as Cd, mg/l	0.003	*BDL(**DL 0.002 mg/l)	*BDL(**DL 0.002 mg/l)	*BDL(**DL 0.002 mg/l)	*BDL(**DL 0.002 mg/l)
21.	Lead (as Pb) mg/l	0.01	*BDL(**DL 0.002 mg/l)	*BDL(**DL 0.002 mg/l)	*BDL(**DL 0.002 mg/l)	*BDL(**DL 0.002 mg/l)
22.	Selenium as Se	0.01	*BDL(**DL 0.001 mg/l)	*BDL(**DL 0.001 mg/l)	*BDL(**DL 0.001 mg/l)	*BDL(**DL 0.001 mg/l)

Sr. No.	Parameters	Acceptable / Permissible Limit (IS 10500: 2012)	Concentration		
			Location		
			Near ETP Security Post, PZ-5	Nr. Old Switch Yard, PZ-6	Dugwell Water, Village-Sakharwahi
			11-04-2022	11-04-2022	11-04-2022
1.	pH value	6.5 to 8.5	7.39	7.46	7.69
2.	Colour, Hazen units	5/15	*BDL(**DL 1)	*BDL(**DL 1)	*BDL(**DL 1)
3.	Turbidity, NTU	1/5	*BDL(**DL 1 NTU)	*BDL(**DL 1 NTU)	*BDL(**DL 1 NTU)
4.	Odour	--	Agreeable	Agreeable	Agreeable
5.	Total Hardness(as CaCO ₃) mg/l	300/600	208.08	165.24	181.56
6.	Calcium (as Ca) ,mg/l	75/200	77.68	37.61	53.96
7.	Total Alkalinity (as CaCO ₃)mg/l	200/600	157.08	120.36	148.92
8.	Chloride (as Cl), mg/l	250/1000	49.03	35.83	46.21
9.	Free Residual Chlorine, mg/l	0.2/1.0	*BDL(**DL 0.15mg/l)	*BDL(**DL 0.15mg/l)	*BDL(**DL 0.15mg/l)
10.	Magnesium (as Mg), mg/l	30/100	3.38	17.30	11.34
11.	Total dissolved solids, mg/l	500/2000	416.0	443.0	498.0
12.	Sulphate (as SO ₄), mg/l	200/400	65.15	53.15	45.86
13.	Fluoride (as F), mg/l	1.0/1.5	0.47	0.44	0.72
14.	Iron (as Fe), mg/l	1.0	BDL(*DL 0.01 mg/l)	BDL(*DL 0.01 mg/l)	BDL(*DL 0.01 mg/l)
15.	Boron (as B) mg/l	0.5/1.0	*BDL(*DL 0.01 mg/l)	*BDL(*DL 0.01 mg/l)	*BDL(*DL 0.01 mg/l)
16.	Total Chromium (as Cr) mg/l	0.05	*BDL(*DL 0.002 mg/l)	*BDL(*DL 0.002 mg/l)	*BDL(*DL 0.002 mg/l)
17.	Zinc (as Zn) mg/l	5/15	BDL(*DL 0.01 mg/l)	BDL(*DL 0.01 mg/l)	BDL(*DL 0.01 mg/l)
18.	Copper (as Cu), mg/l	0.05/1.5	* BDL(**DL 0.002 mg/l)	* BDL(**DL 0.002 mg/l)	* BDL(**DL 0.002 mg/l)
19.	Manganese (as Mn), mg/l	0.1/0.3	*BDL(**DL 0.01 mg/l)	*BDL(**DL 0.01 mg/l)	*BDL(**DL 0.01 mg/l)
20.	Cadmium as Cd, mg/l	0.003	*BDL(**DL 0.002 mg/l)	*BDL(**DL 0.002 mg/l)	*BDL(**DL 0.002 mg/l)
21.	Lead (as Pb) mg/l	0.01	*BDL(**DL 0.002 mg/l)	*BDL(**DL 0.002 mg/l)	*BDL(**DL 0.002 mg/l)
22.	Selenium as Se	0.01	*BDL(**DL 0.001 mg/l)	*BDL(**DL 0.001 mg/l)	*BDL(**DL 0.001 mg/l)

23.	Total Arsenic (as As) mg/l	0.01/0.05	*BDL(**DL 0.002 mg/l)	*BDL(**DL 0.002 mg/l)	*BDL(**DL 0.002 mg/l)	
24.	Mercury (as Hg) mg/l	0.001	*BDL (**DL 0.0005 mg/l)	*BDL (**DL 0.0005 mg/l)	*BDL (**DL 0.0005 mg/l)	

Note: 1) All the above Ground Water Quality Analysis were done by MOEF Approved 3rd party M/s Vardan EnviroLab

2) Information given to local panchayat through DIL CSR team for the necessary treatment & assistance.

Sr. No.	Parameters	Acceptable / Permissible Limit (IS 10500: 2012)	Concentration			
			Location			
			Dugwell Water, Village-Pandharkawda)	Borewell Water, Village-Sonegaon)	Dugwell Water, Village-Yerur)	Borewell Water, Village-Wandhri
			21-07-2022	21-07-2022	21-07-2022	21-07-2022
1.	pH value	6.5 to 8.5	7.32	7.55	7.39	7.65
2.	Colour, Hazen units	5/15	*BDL(**DL 1)	*BDL(**DL 1)	*BDL(**DL 1)	*BDL(**DL 1)
3.	Turbidity, NTU	1/5	*BDL(**DL 1 NTU)	*BDL(**DL 1 NTU)	*BDL(**DL 1 NTU)	*BDL(**DL 1 NTU)
4.	Odour	--	Agreeable	Agreeable	Agreeable	Agreeable
5.	Total Hardness(as CaCO ₃) mg/l	300/600	158.40	188.10	143.6	306.90
6.	Calcium (as Ca) ,mg/l	75/200	41.66	57.58	49.6	95.23
7.	Total Alkalinity (as CaCO ₃)mg/l	200/600	196.0	203.50	189.6	198.90
8.	Chloride (as Cl), mg/l	250/1000	62.30	147.26	142.5	187.64
9.	Free Residual Chlorine, mg/l	0.2/1.0	*BDL(**DL 0.15mg/l)	*BDL(**DL 0.15mg/l)	*BDL(**DL 0.15mg/l)	*BDL(**DL 0.15mg/l)
10.	Magnesium (as Mg), mg/l	30/100	13.18	14.37	4.8	16.72
11.	Total dissolved solids, mg/l	500/2000	510.0	635.0	550.0	765.0
12.	Sulphate (as SO ₄), mg/l	200/400	52.34	61.06	63.9	44.97
13.	Fluoride (as F), mg/l	1.0/1.5	0.62	0.95	0.9	0.92
14.	Iron (as Fe), mg/l	1.0	0.45	0.35	BDL(*DL 0.01 mg/l)	0.41
15.	Boron (as B) mg/l	0.5/1.0	*BDL(*DL 0.01 mg/l)	*BDL(*DL 0.01 mg/l)	*BDL(*DL 0.01 mg/l)	*BDL(*DL 0.01 mg/l)
16.	Total Chromium (as Cr) mg/l	0.05	*BDL(*DL 0.002 mg/l)	*BDL(*DL 0.002 mg/l)	*BDL(*DL 0.002 mg/l)	*BDL(*DL 0.002 mg/l)
17.	Zinc (as Zn) mg/l	5/15	BDL(*DL 0.01 mg/l)	0.40	BDL(*DL 0.01 mg/l)	0.59
18.	Copper (as Cu), mg/l	0.05/1.5	* BDL(**DL 0.002 mg/l)	* BDL(**DL 0.002 mg/l)	* BDL(**DL 0.002 mg/l)	* BDL(**DL 0.002 mg/l)
19.	Manganese (as Mn), mg/l	0.1/0.3	*BDL(**DL 0.01 mg/l)	*BDL(**DL 0.01 mg/l)	*BDL(**DL 0.01 mg/l)	*BDL(**DL 0.01 mg/l)
20.	Cadmium as Cd, mg/l	0.003	*BDL(**DL 0.002 mg/l)	*BDL(**DL 0.002 mg/l)	*BDL(**DL 0.002 mg/l)	*BDL(**DL 0.002 mg/l)
21.	Lead (as Pb) mg/l	0.01	*BDL(**DL 0.002 mg/l)	*BDL(**DL 0.002 mg/l)	*BDL(**DL 0.002 mg/l)	*BDL(**DL 0.002 mg/l)
22.	Selenium as Se	0.01	*BDL(**DL 0.001 mg/l)	*BDL(**DL 0.001 mg/l)	*BDL(**DL 0.001 mg/l)	*BDL(**DL 0.001 mg/l)
23.	Total Arsenic (as As)	0.01/0.05	*BDL(**DL 0.002 mg/l)	*BDL(**DL 0.002 mg/l)	*BDL(**DL 0.002 mg/l)	*BDL(**DL 0.002 mg/l)

	mg/l					
24.	Mercury (as Hg) mg/l	0.001	*BDL (**DL 0.0005 mg/l)	*BDL (**DL 0.0005 mg/l)	*BDL (**DL 0.0005 mg/l)	*BDL (**DL 0.0005 mg/l)
Note: 1) All the above Ground Water Quality Analysis were done by MOEF Approved 3rd party M/s Vardan EnviroLab 2) Information given to local panchayat through DIL CSR team for the necessary treatment & assistance.						

Sr. No.	Parameters	Acceptable / Permissible Limit (IS 10500: 2012)	Concentration			
			Location			
			Dugwell Water, Village-Morwa)	Dugwell Water, Village – Ghodpeth)	Dugwell Water, Village – Tadali)	Ground Water from Intake Well near Wadha Village
			21-07-2022	21-07-2022	21-07-2022	21-07-2022
1.	pH value	6.5 to 8.5	7.70	7.51	7.75	7.71
2.	Colour, Hazen units	5/15	*BDL(**DL 1)	*BDL(**DL 1)	*BDL(**DL 1)	*BDL(**DL 1)
3.	Turbidity, NTU	1/5	*BDL(**DL 1 NTU)	*BDL(**DL 1 NTU)	*BDL(**DL 1 NTU)	*BDL(**DL 1 NTU)
4.	Odour	--	Agreeable	Agreeable	Agreeable	Agreeable
5.	Total Hardness(as CaCO ₃) mg/l	300/600	277.20	267.30	287.10	207.90
6.	Calcium (as Ca) ,mg/l	75/200	67.45	75.39	93.25	35.71
7.	Total Alkalinity (as CaCO ₃)mg/l	200/600	212.80	222.0	231.30	249.80
8.	Chloride (as Cl), mg/l	250/1000	204.26	92.63	125.88	32.78
9.	Free Residual Chlorine, mg/l	0.2/1.0	*BDL(**DL 0.15mg/l)	*BDL(**DL 0.15mg/l)	*BDL(**DL 0.15mg/l)	*BDL(**DL 0.15mg/l)
10.	Magnesium (as Mg), mg/l	30/100	26.38	19.15	13.12	28.83
11.	Total dissolved solids, mg/l	500/2000	762.0	596.0	724.0	645.0
12.	Sulphate (as SO ₄), mg/l	200/400	85.14	62.11	81.65	35.03
13.	Fluoride (as F), mg/l	1.0/1.5	0.53	0.69	0.81	0.23
14.	Iron (as Fe), mg/l	1.0	0.37	0.46	0.41	0.37
15.	Boron (as B) mg/l	0.5/1.0	*BDL(*DL 0.01 mg/l)	*BDL(*DL 0.01 mg/l)	*BDL(*DL 0.01 mg/l)	*BDL(*DL 0.01 mg/l)
16.	Total Chromium (as Cr) mg/l	0.05	*BDL(*DL 0.002 mg/l)	*BDL(*DL 0.002 mg/l)	BDL(*DL 0.01 mg/l)	*BDL(*DL 0.002 mg/l)
17.	Zinc (as Zn) mg/l	5/15	0.23	0.37	0.38	0.42
18.	Copper (as Cu), mg/l	0.05/1.5	* BDL(**DL 0.002 mg/l)	* BDL(**DL 0.002 mg/l)	*BDL(**DL 0.01 mg/l)	* BDL(**DL 0.002 mg/l)
19.	Manganese (as Mn), mg/l	0.1/0.3	*BDL(**DL 0.01 mg/l)	*BDL(**DL 0.01 mg/l)	*BDL(**DL 0.002 mg/l)	*BDL(**DL 0.01 mg/l)
20.	Cadmium as Cd, mg/l	0.003	*BDL(**DL 0.002 mg/l)	*BDL(**DL 0.002 mg/l)	*BDL(**DL 0.002 mg/l)	*BDL(**DL 0.002 mg/l)
21.	Lead (as Pb) mg/l	0.01	*BDL(**DL 0.002 mg/l)	*BDL(**DL 0.002 mg/l)	*BDL(**DL 0.001 mg/l)	*BDL(**DL 0.002 mg/l)
22.	Selenium as Se	0.01	*BDL(**DL 0.001 mg/l)	*BDL(**DL 0.001 mg/l)	*BDL(**DL 0.002 mg/l)	*BDL(**DL 0.001 mg/l)

Sr. No.	Parameters	Acceptable / Permissible Limit (IS 10500: 2012)	Concentration			
			Location			
			Near Recovery Pump House-I,(Ash Pond) PZ-1	Near Recovery Pump House-II,(Ash Bund) PZ-2	Ash Pond II, PZ-3	Near Railway Crossing of WB-2, PZ-4
			21-07-2022	21-07-2022	22-07-2022	22-07-2022
1.	pH value	6.5 to 8.5	7.15	7.42	7.62	7.62
2.	Colour, Hazen units	5/15	*BDL(**DL 1)	1	*BDL(**DL 1)	1
3.	Turbidity, NTU	1/5	*BDL(**DL 1 NTU)	*BDL(**DL 1 NTU)	*BDL(**DL 1 NTU)	*BDL(**DL 1 NTU)
4.	Odour	--	Agreeable	Agreeable	Agreeable	Agreeable
5.	Total Hardness(as CaCO ₃) mg/l	300/600	188.10	207.90	173.25	212.85
6.	Calcium (as Ca) ,mg/l	75/200	43.65	55.55	47.62	45.63
7.	Total Alkalinity (as CaCO ₃)mg/l	200/600	157.30	161.90	146.8	171.10
8.	Chloride (as Cl), mg/l	250/1000	76.0	78.38	135.38	83.13
9.	Free Residual Chlorine, mg/l	0.2/1.0	*BDL(**DL 0.15mg/l)	*BDL(**DL 0.15mg/l)	*BDL(**DL 0.15mg/l)	*BDL(**DL 0.15mg/l)
10.	Magnesium (as Mg), mg/l	30/100	19.19	16.17	13.17	24.0
11.	Total dissolved solids, mg/l	500/2000	438.0	432.0	422.0	488.0
12.	Sulphate (as SO ₄), mg/l	200/400	52.06	53.46	51.78	61.0
13.	Fluoride (as F), mg/l	1.0/1.5	0.47	0.29	0.28	0.41
14.	Iron (as Fe), mg/l	1.0	0.45	0.34	0.40	0.48
15.	Boron (as B) mg/l	0.5/1.0	*BDL(*DL 0.01 mg/l)	*BDL(*DL 0.01 mg/l)	*BDL(*DL 0.01 mg/l)	*BDL(*DL 0.01 mg/l)
16.	Total Chromium (as Cr) mg/l	0.05	*BDL(*DL 0.002 mg/l)	*BDL(*DL 0.002 mg/l)	*BDL(*DL 0.002 mg/l)	*BDL(*DL 0.002 mg/l)
17.	Zinc (as Zn) mg/l	5/15	0.36	0.30	0.34	0.34
18.	Copper (as Cu), mg/l	0.05/1.5	* BDL(**DL 0.002 mg/l)	* BDL(**DL 0.002 mg/l)	* BDL(**DL 0.002 mg/l)	* BDL(**DL 0.002 mg/l)
19.	Manganese (as Mn), mg/l	0.1/0.3	*BDL(**DL 0.01 mg/l)	*BDL(**DL 0.01 mg/l)	*BDL(**DL 0.01 mg/l)	*BDL(**DL 0.01 mg/l)
20.	Cadmium as Cd, mg/l	0.003	*BDL(**DL 0.002 mg/l)	*BDL(**DL 0.002 mg/l)	*BDL(**DL 0.002 mg/l)	*BDL(**DL 0.002 mg/l)
21.	Lead (as Pb) mg/l	0.01	*BDL(**DL 0.002 mg/l)	*BDL(**DL 0.002 mg/l)	*BDL(**DL 0.002 mg/l)	*BDL(**DL 0.002 mg/l)
22.	Selenium as Se	0.01	*BDL(**DL 0.001 mg/l)	*BDL(**DL 0.001 mg/l)	*BDL(**DL 0.001 mg/l)	*BDL(**DL 0.001 mg/l)
23.	Total Arsenic (as As) mg/l	0.01/0.05	*BDL(**DL 0.002 mg/l)	*BDL(**DL 0.002 mg/l)	*BDL(**DL 0.002 mg/l)	*BDL(**DL 0.002 mg/l)

24.	Mercury (as Hg) mg/l	0.001	*BDL (**DL 0.0005 mg/l)	*BDL (**DL 0.0005 mg/l)	*BDL (**DL 0.0005 mg/l)	*BDL (**DL 0.0005 mg/l)
<p>Note: 1) All the above Ground Water Quality Analysis were done by MOEF Approved 3rd party M/s Vardan EnviroLab</p> <p>2) Information given to local panchayat through DIL CSR team for the necessary treatment & assistance.</p>						

Sr. No.	Parameters	Acceptable / Permissible Limit (IS 10500: 2012)	Concentration		
			Location		
			Near ETP Security Post, PZ-5	Nr. Old Switch Yard, PZ-6	Dugwell Water, Village-Sakharwahi
			22-07-2022	12-02-2022	21-07-2022
1.	pH value	6.5 to 8.5	7.62	7.42	7.59
2.	Colour, Hazen units	5/15	*BDL(**DL 1)	*BDL(**DL 1)	*BDL(**DL 1)
3.	Turbidity, NTU	1/5	*BDL(**DL 1 NTU)	*BDL(**DL 1 NTU)	*BDL(**DL 1 NTU)
4.	Odour	--	Agreeable	Agreeable	Agreeable
5.	Total Hardness(as CaCO ₃) mg/l	300/600	202.95	161.02	178.20
6.	Calcium (as Ca) ,mg/l	75/200	71.42	35.77	47.82
7.	Total Alkalinity (as CaCO ₃)mg/l	200/600	152.60	116.64	143.40
8.	Chloride (as Cl), mg/l	250/1000	68.88	32.78	95.01
9.	Free Residual Chlorine, mg/l	0.2/1.0	*BDL(**DL 0.15mg/l)	*BDL(**DL 0.15mg/l)	*BDL(**DL 0.15mg/l)
10.	Magnesium (as Mg), mg/l	30/100	5.93	17.40	14.38
11.	Total dissolved solids, mg/l	500/2000	488.0	440.0	486.0
12.	Sulphate (as SO ₄), mg/l	200/400	63.97	51.0	42.99
13.	Fluoride (as F), mg/l	1.0/1.5	0.53	0.40	0.52
14.	Iron (as Fe), mg/l	1.0	0.37	BDL(*DL 0.01 mg/l)	0.36
15.	Boron (as B) mg/l	0.5/1.0	*BDL(*DL 0.01 mg/l)	*BDL(*DL 0.01 mg/l)	*BDL(*DL 0.01 mg/l)
16.	Total Chromium (as Cr) mg/l	0.05	*BDL(*DL 0.002 mg/l)	*BDL(*DL 0.002 mg/l)	*BDL(*DL 0.002 mg/l)
17.	Zinc (as Zn) mg/l	5/15	0.46	BDL(*DL 0.01 mg/l)	0.41
18.	Copper (as Cu), mg/l	0.05/1.5	* BDL(**DL 0.002 mg/l)	* BDL(**DL 0.002 mg/l)	* BDL(**DL 0.002 mg/l)
19.	Manganese (as Mn), mg/l	0.1/0.3	*BDL(**DL 0.01 mg/l)	*BDL(**DL 0.01 mg/l)	*BDL(**DL 0.01 mg/l)
20.	Cadmium as Cd, mg/l	0.003	*BDL(**DL 0.002 mg/l)	*BDL(**DL 0.002 mg/l)	*BDL(**DL 0.002 mg/l)
21.	Lead (as Pb) mg/l	0.01	*BDL(**DL 0.002 mg/l)	*BDL(**DL 0.002 mg/l)	*BDL(**DL 0.002 mg/l)
22.	Selenium as Se	0.01	*BDL(**DL 0.001 mg/l)	*BDL(**DL 0.001 mg/l)	*BDL(**DL 0.001 mg/l)
23.	Total Arsenic (as As) mg/l	0.01/0.05	*BDL(**DL 0.002 mg/l)	*BDL(**DL 0.002 mg/l)	*BDL(**DL 0.002 mg/l)

24.	Mercury (as Hg) mg/l	0.001	*BDL (**DL 0.0005 mg/l)	*BDL (**DL 0.0005 mg/l)	*BDL (**DL 0.0005 mg/l)	
<p>Note: 1) All the above Ground Water Quality Analysis were done by MOEF Approved 3rd party M/s Vardan EnviroLab</p> <p>2) Information given to local panchayat through DIL CSR team for the necessary treatment & assistance.</p>						

Annexure- 2

STACK EMISSION QUALITY STATUS APRIL-2022 TO SEPTEMBER-2022

Sr. No.	Parameters	Concentration											
		April-22		May-22		June-22		July-22		August-22		September-22	
		TPP Unit I	TPP Unit II	TPP Unit I	TPP Unit II	TPP Unit I	TPP Unit II	TPP Unit I	TPP Unit II	TPP Unit I	TPP Unit II	TPP Unit I	TPP Unit II
1.	Total Particulate Matter, mg/Nm ³	30.97	28.69	32.96	30.77	34.99	27.98	25.51	32.68	28.82	36.60	30.08	33.74
2.	Sulphur Dioxide as SO ₂ , mg/Nm ³	1051.44	1002.88	1011.85	1013.35	984.22	1022.45	1105.27	1034.81	1278.95	1328.13	1264.42	1118.85
3.	Sulphur Dioxide as SO ₂ , Kg/Hr	1750.44	1656.48	1704.14	1688.94	1678.40	1698.23	1437.60	1238.35	1612.65	1753.21	1508.56	1382.65
4.	Oxides of Nitrogen as NO ₂ ,mg/Nm ³	419.68	366.88	399.37	379.07	318.59	367.67	433.98	382.12	430.76	379.31	424.73	402.41
5.	Oxides of Nitrogen as NO ₂ , ppm	223.04	194.98	212.25	201.46	169.33	195.42	230.66	203.10	228.95	201.61	225.75	213.88
6.	Mercury as Hg, mg/Nm ³	0.004	0.005	0.003	0.004	BLQ	BLQ	BLQ	BLQ	BLQ	BLQ	BLQ	BLQ

Note:All the above Stack monitoring &Analysis were done by MOEF Approved 3rd party M/s Vardan Enviro Lab

STACK EMISSION QUALITY STATUS – APRIL-2022 TO SEPTEMBER-2022

Sr. No	Parameters	April-2022				July-2022			
		D.G. Set No.1 1500 KVA (Left Bank)	D.G. Set No.2 1500 KVA (Left Bank)	D.G. Set No.1 1500 KVA (Right Bank)	D.G. Set No.2 1500 KVA (Right Bank)	D.G. Set No.1 1500 KVA (Left Bank)	D.G. Set No.2 1500 KVA (Left Bank)	D.G. Set No.1 1500 KVA (Right Bank)	D.G. Set No.2 1500 KVA (Right Bank)
1.	Total Particulate Matter, mg/Nm ³	26.12	24.79	28.45	27.81	34.52	38.94	41.12	43.17
2.	Sulphur Dioxide as SO ₂ , mg/ Nm ³	47.42	49.93	50.17	40.48	42.52	49.93	54.33	39.81
3.	Sulphur Dioxide as SO ₂ , Kg/Hr	0.18	0.19	0.20	0.16	0.12	0.14	0.15	0.11
4.	Oxides of Nitrogen as NO ₂ ,mg/Nm ³	120.49	140.80	132.67	136.74	192.59	186.29	163.01	196.27
5.	Oxides of Nitrogen as NO ₂ , ppm	64.04	74.83	70.51	72.67	78.74	70.98	64.18	76.33
Note:All the above Stack monitoring &Analysis were done by MOEF Approved 3 rd party M/s Vardan Enviro Lab									

Annexure-3

DHARIWAL INFRASTRUCTURE LIMITED

Monthly Ash Generation and Utilization (For the Period from 1st April 2022 to 30th September 2022)

ASH GENERATION AND UTILIZATION (in MT)

Sl. No.	Month	Ash Generation	Ash Utilization	Ash based/ Bricks/ Blocks/ Tiles etc.	In manufacture of Cement	In construction of Highways & Roads including Flyovers	In Ash dyke raising	In reclamation of low lying Area	In Mine filling	Unutilized Ash	Ash Utilization %
1	Apr-22	89964	89964	7617	82347	0	0	0	0	0	100.00
2	May-22	85992	85992	8149	77683	160	0	0	0	0	100.00
3	Jun-22	103270	103270	9679	93435	156	0	0	0	0	100.00
4	Jul-22	72498	72498	7558	64844	96	0	0	0	0	100.00
5	Aug-22	84629	84629	6392	76892	1345	0	0	0	0	100.00
6	Sep-22	105504	105504	11944	91638	1922	0	0	0	0	100.00
Total		541857	541857	51339	486839	3679	0	0	0	0	100

Annexure –4

EFFLUENT QUALITY STATUS

EFFLUENT QUALITY MONITORING REPORT –APRIL-2022 TO SEPTEMBER-2022									
Sr. No.	Parameter	NORMS	ETP Outlet	April-22	May-22	June-22	July-22	Aug-22	Sep-22
1.	pH	6.5 to 8.5		7.72	7.78	8.01	7.91	7.71	7.78
2.	Total Suspended Solid	100 mg/l		10.0	10.40	15.0	9.40	8.40	8.20
3.	Oil & Grease	10 mg/l		*BDL (**DL 0.4)	*BDL (**DL 0.4)	*BDL (**DL 0.4)	0.60	0.80	0.60
4.	Biochemical Oxygen Demand (3 days/27°C)	30 mg/l		15.27	15.50	17.0	13.44	11.03	30.0
5.	Chemical Oxygen demand	250 mg/l		70.60	65.40	83.0	65.92	61.74	65.28
6.	Total Dissolved Solid	2100 mg/l		1060.0	1288.0	953.33	1048.0	1034.0	1030.0
Note: The Effluent Quality monitoring done MOEF approved 3rd party M/s Vardan EnviroLab									

EFFLUENT QUALITY MONITORING REPORT – APRIL-2022 TO SEPTEMBER-2022

Sl.No.	Parameter	Norms	Condenser cooling Water	April-22		May-22		June-22		July-22		Aug-22		Sep-22	
				unit – I	unit - II	unit - I	unit - II	unit - I	unit - II	unit - I	unit – II	unit - I	unit - II	unit - I	unit - II
1	PH	5.5 - 9.0		7.79	7.87	7.79	7.75	7.79	7.75	7.59	7.92	7.65	7.95	7.85	7.40
2	Free Available Chlorine	0.5 mg/l		0.29	0.38	0.29	0.33	0.29	0.33	0.35	0.35	0.49	0.46	0.88	0.42
3	Temp.	<5°C higher than Intake water		1.14	1.16	1.12	1.15	1.12	1.15	1.17	1.09	1.4	1.3	1.3	1.4
Note:	Effluent Quality monitoring done by MoEF approved 3rd party M/s Vardan EnviroLab														

EFFLUENT QUALITY MONITORING REPORT – APRIL-2022 TO SEPTEMBER-2022

Sl.No.	Parameter	Norms	Boiler Blow Down	April-22		May-22		June-22		July-22		Aug-22		Sep-22	
				unit - I	unit - II	unit - I	unit - II	unit - I	unit - II	unit - I	unit - II	unit - I	unit - II	unit - I	unit - II
1	Total Suspended solid	100 mg/l		18.0	14.0	12.8	11.2	21.0	12.3 0	17.2 0	18.8 0	15.2 0	19.4 0	16.6 0	19.80
2	Oil & Grease	10 mg/l		BDL	BDL	BDL	BDL	BDL	BDL	0.40	0.80	0.50	0.60	0.40	0.80
3	Copper(Total)	1 mg/l		0.05	0.04	0.04	0.03	BDL	BDL	BDL	BDL	0.00 25	BDL	BDL	BDL
4	Iron(Total),mg/l	1 mg/l	0.27	0.22	0.27	0.21	BDL	BDL	0.12	BDL	BDL	BDL	BDL	BDL	
Note:	The Effluent Quality monitoring done by MoEF approved M/s Vardan EnviroLab														

EFFLUENT QUALITY MONITORING REPORT – APRIL-2022 TO SEPTEMBER-2022															
Sl.No.	Parameter	Norms	Cooling tower blow down	April-22		May-22		June-22		July-22		Aug-22		Sep-22	
				unit - I	unit - II	unit - I	unit - II	unit - I	unit - II	unit - I	unit - II	unit - I	unit - II	unit - I	unit - II
1	Free Available chlorine	0.5 mg/l		0.28	0.28	0.26	0.24	0.32	0.21	0.28	0.24	0.31	0.21	BLQ	0.23
2	Zinc	1 mg/l		0.28	0.37	0.21	0.30	BLQ	BLQ	BLQ	BLQ	BLQ	BLQ	BLQ	BLQ
3	Chromium (Total)	0.2 mg/l		0.14	0.19	0.10	0.12	BLQ	BLQ	BLQ	BLQ	0.07 4	0.07 5	0.06 3	0.05 9
4	Phosphate	5 mg/l		2.24	2.14	2.60	2.27	3.42	1.75	2.38	2.34	2.89	3.11	0.31	0.28
Note:	The Effluent Quality Monitoring done by MoEF approved 3rd Party M/s Vardan EnviroLab														

Note: The Effluent Quality Monitoring done by MoEF approved 3rd Party M/s Vardan EnviroLab

EFFLUENT QUALITY MONITORING REPORT – APRIL-2022 TO SEPTEMBER-2022

[illegible]

EFFLUENT QUALITY MONITORING REPORT – APRIL-2022 TO SEPTEMBER-2022

Sl.No.	Parameter	Norms	Unit	STP Treated Effluent	April-22	May-22	June-22	July-22	Aug-22	Sep-22
1	PH	6.5-9.0			7.38	7.63	7.64	7.14	7.21	7.24
2	Total Suspended Solids (TSS)	50	mg/L		14.0	6.8	16.0	12.60	10.20	10.80
3	BOD	30	mg/L		12.0	9.05	13.0	13.27	11.17	12.0
Note:	Effluent Quality Monitoring done by MoEF approved 3rd Party M/s Vardan EnviroLab									

Annexure-5



भारत सरकार

Government of India

वाणिज्य और उद्योग मंत्रालय

Ministry of Commerce & Industry

पेट्रोलियम तथा विस्फोटक सुरक्षा संगठन (पैसो)

Petroleum & Explosives Safety Organisation (PESO)

प्लॉट संख्या 36-37, वार्ड संख्या 38, राठी लेआउट, राष्ट्रभाषा मार्ग, वर्धा

वर्धा- 442001

Plot no. 36-37, Ward no. 38, Rathi Layout, Rashtrabhasha Road, Wardha-(Maharashtra),
Wardha - 442001

Regd/AD

E-mail : dyccewardha@explosives.gov.in

Phone/Fax No : 7152230370

संख्या /No. : P/HQ/MH/15/6129 (P294572)

दिनांक /Dated : 15/01/2018

सेवा में /To,

M/s. Dhariwal Infrastructure Ltd.,
C-6 Tadali, MIDC Growth Centre,,
NA,
Tadali,
Chandrapur,
Taluka: Nagbhir,
District: CHANDRAPUR,
State: Maharashtra
PIN: 442406

विषय /Sub: Plot No, Plot No.C-6,, M.I.D.C.Tadali,, Village-MIDC Tadali,, Taluka: Chandrapur, District: CHANDRAPUR, State: Maharashtra, PIN: 442406
में स्थित विद्यमान पेट्रोलियम वर्ग C अधिष्ठापन में अनुज्ञप्ति सं P/HQ/MH/15/6129 (P294572) के नवीकरण के संदर्भ में ।
Existing Petroleum Class C Installation at Plot No, Plot No.C-6,, M.I.D.C.Tadali,, Village-MIDC Tadali,, Taluka: Chandrapur, District:
CHANDRAPUR, State: Maharashtra, PIN: 442406 - Licence No. P/HQ/MH/15/6129 (P294572) - Renewal regarding

महोदय /Sir
(:).

कृपया आपके पत्र क्रमांक Nil दिनांक 30/11/2017 का अवलोकन करें ।
Please refer to your letter No. : Nil, dated 30/11/2017

अनुज्ञप्ति संख्या P/HQ/MH/15/6129 (P294572) दिनांक 23/01/2013 को दिनांक 31/12/2022 तक नवीनीकृत कर इस पत्र के साथ अग्रहित की जा रही है ।
Licence No. P/HQ/MH/15/6129 (P294572) dated 23/01/2013 is forwarded herewith duly renewed upto 31/12/2022

कृपया पेट्रोलियम नियम 2002 के अधीन बनाए गए नियम 148 में दी गई प्रक्रिया का कड़ाई से पालन करें । अनुज्ञप्ति के नवीकरण हेतु समस्त दस्तावेजों को अनुज्ञप्ति की वैधता समाप्त होने की तिथि से कम से कम 30 दिन पूर्व कार्यालय को प्रेषित करें ।

Please follow the procedure strictly as laid down in rule 148 of the Petroleum Rules, 2002 and submit complete documents for the Renewal of the licence so as to reach this office on or before the date on which Licence expires.

कृपया पावती दें।
Please acknowledge the receipt

भवदीय /Yours faithfully,

(श्रीमती विजया-संजय बारदेव)
(Mrs. Vijaya Sanjay Bardeo)

Dy. Controller of Explosives
कुल विस्फोटक नियंत्रक
For Controller of Explosives
वर्धा/Wardha

(अधिक जानकारी जैसे आवेदन की स्थिति, शुल्क तथा अन्य विवरण के लिए हमारी वेबसाइट : <http://peso.gov.in> देखें)
(For more information regarding status, fees and other details please visit our website : <http://peso.gov.in>)

प्ररूप XV
(प्रथम अनुसूची का अनुच्छेद 6 देखिए)
FORM XV
(see Article 6 of the First Schedule)



अधिष्ठापनों में पेट्रोलियम के आयात और भंडारण के लिए अनुज्ञप्ति
LICENCE TO IMPORT AND STORE PETROLEUM IN AN INSTALLATION

अनुज्ञप्ति सं. (Licence No.): P/HQ/MH/15/6129(P294572)

फीस रूपए (Fee Rs.) 15000/- per year

M/s. Dhariwal Infrastructure Ltd., C-6 Tadali, MIDC Growth Centre,, NA, Tadali, Chandrapur, Taluka: Nagbhir, District: CHANDRAPUR, State: Maharashtra, PIN: 442406 को केवल इसमें यथा विनिर्दिष्ट वर्ग और मात्राओं में पेट्रोलियम 2000.00 KL आयात करने के लिए और उसका नीचे वर्णित और अनुमोदित नक्शा संख्या P/HQ/MH/15/6129(P294572) तारीख 29/10/2014 जो कि इससे उपाबद्ध है, में दिखाए गए स्थान पर भण्डारण के लिए पेट्रोलियम अधिनियम, 1934 के उपबंधों या उसके अधीन बनाए गए नियमों तथा इस अनुज्ञप्ति की अतिरिक्त शर्तों के अधीन रहते हुए, यह अनुज्ञप्ति अनूदत्त की जाती है।

Licence is hereby granted to M/s. Dhariwal Infrastructure Ltd., C-6 Tadali, MIDC Growth Centre,, NA, Tadali, Chandrapur, Taluka: Nagbhir, District: CHANDRAPUR, State: Maharashtra, PIN: 442406 valid only for the importation and storage of 2000.00 KL Petroleum of the class and quantities as herein specified and storage thereof in the place described below and shown on the approved plan No P/HQ/MH/15/6129(P294572) dated 29/10/2014 attached hereto subject to the provisions of the Petroleum Act, 1934 and the rule made thereunder and to the further conditions of this Licence.

यह अनुज्ञप्ति 31st day of December 2022 तक प्रवृत्त रहेगी।
The Licence shall remain in force till the 31st day of December 2022

पेट्रोलियम का विवरण /Description of Petroleum

अनुज्ञप्त मात्रा (किलोलीटरों में) /Quantity licenced in KL

वर्ग क प्रपुंज पेट्रोलियम /Petroleum Class A in bulk	NIL
वर्ग क प्रपुंज पेट्रोलियम से भिन्न /Petroleum Class A, otherwise than in bulk	NIL
वर्ग ख प्रपुंज पेट्रोलियम /Petroleum Class B in bulk	NIL
वर्ग ख प्रपुंज पेट्रोलियम से भिन्न /Petroleum Class B, otherwise than in bulk	NIL
वर्ग ग प्रपुंज पेट्रोलियम /Petroleum Class C in bulk	2000.00 KL
वर्ग ग प्रपुंज पेट्रोलियम से भिन्न /Petroleum Class C, otherwise than in bulk	NIL

कुल क्षमता /Total Capacity

2000.00 KL

January 23, 2013

For Chief Controller of Explosives
HQ, Nagpur

अनुज्ञप्त परिसरों का विवरण और अवस्थान

DESCRIPTION AND LOCATION OF THE LICENSED PREMISES

अनुज्ञप्त परिसर जिसकी विन्यास सोमाएं अन्य विशिष्टयां संलग्न अनुमोदित नक्शों में दिखाई गई हैं Plot No: Plot No.C-6,, M.I.D.C.Tadali,, Village-MIDC Tadali,, Taluka: Chandrapur, District: CHANDRAPUR, State: Maharashtra, PIN: 442406 स्थान पर अवस्थित है तथा उसमें निम्नलिखित Two aboveground petroleum class C(FO/LDO) storage tanks togetherwith connected facilities. सम्मिलित हैं।

The licensed premises, the layout, boundaries and other particulars of which are shown in the attached approved plan are situated at Plot No: Plot No.C-6,, M.I.D.C.Tadali,, Village-MIDC Tadali,, Taluka: Chandrapur, District: CHANDRAPUR, State: Maharashtra, PIN: 442406 and consists of Two aboveground petroleum class C(FO/LDO) storage tanks togetherwith connected facilities. together with connected facilities.

अनुज्ञप्ति संख्या-(Licence No.) P/HQ/MH/15/6129 (P294572)

नवीनीकरण के पृष्ठांकन के लिए स्थान
SPACE FOR ENDORSEMENT OF RENEWALS

पेट्रोलियम अधिनियम, १९३४ के उपबन्धों या उनके अधीन बनाए गए नियमों या इस अनुज्ञप्ति की शर्तों का उल्लंघन न होने की दशा में यह अनुज्ञप्ति फ़िस में बिना किसी छूट के दस वर्ष तक नवीकृत की जा सकती है।
 This licence shall be renewable without any concession in fee for ten years in the absence of contravention of any provisions of the Petroleum Act, 1934 or of the rules framed thereunder or of any of the conditions of this licence.

	Date of Renewal	Date of Expiry of license	अनुज्ञापन प्राधिकारी के हस्ताक्षर और स्टाम्प Signature and office stamp of the licencing authority.
1).	10/01/2014	31/12/2014	Sd/- C.G.Kaiambhe Dy. Chief Controller of Explosives For Controller of Explosives Wardha
2).	13/03/2015	31/12/2015	Sd/- H K Sharma Controller of Explosives Wardha
3).	10/11/2015	31/12/2016	Sd/- H K Sharma Controller of Explosives Wardha
4).	29/12/2016	31/12/2017	Sd/- H K Sharma Controller of Explosives Wardha
5).	15/01/2018	31/12/2022	Mrs. Vijaya Sanjay Bardeo Dy. Controller of Explosives For Controller of Explosives Wardha विस्फोटक निर्वहक, वर्धा Controller of Explosives, Wardha.


यदि अनुज्ञप्ति परिसर इसमें उपाबद्ध विवरण और शर्तों के अनुरूप नहीं पाए जाते हैं और जिन नियमों और शर्तों के अधीन यह अनुज्ञप्ति मंजूर की गई है उनमें से किसी का उल्लंघन होने की दशा में यह अनुज्ञप्ति रद्द की जा सकती है और अनुज्ञप्तिधारी प्रथम अपराध के लिए साधारण कारावास से, जो एक मास तक हो सकता है, या जुर्माने से, जो एक हजार रुपये तक हो सकता है, या दोनों से, और प्रत्येक पश्चातवर्ती अपराध के लिए साधारण कारावास से जो तीन मास तक हो सकता है, या जुर्माने से, जो पांच हजार रुपये तक हो सकता है, या दोनों से, दण्डनीय होगा।

This licence is liable to be cancelled if the licensed premises are not found conforming to the description given on the approved plan attached hereto and contravention of any of the rules and conditions under which this licence is granted and the holder of this licence is also punishable for the first offence with simple imprisonment which may be extend to one month, or with fine which may extend to one thousand rupees, or with both and for every subsequent offence with simple imprisonment which may extend to three months, or with fine which may extend to five thousand rupees or with both.

Annexure-6

Photographs of Plantation inside Plant Premises





Annexure-7(A)

AMBIENT NOISEQUALITY STATUS

Location			AAQMS Cabin-01 (Near VIP Gate)		AAQMS Cabin-02 (Near ETP & RWH Pond)		AAQMS Cabin-03 (Near Old Switch Yard)	
Parameters	Month	Reading	During Day Time	During Night Time	During Day Time	During Night Time	During Day Time	During Night Time
Noise Level in dB (A)	APRIL-2022	Leq	66.59	56.43	60.36	50.14	63.26	52.78
	MAY-2022	Leq	63.94	52.51	61.14	50.02	62.64	53.82
	JUNE-2022	Leq	66.15	54.98	60.22	51.47	62.95	52.38
	JULY-2022	Leq	63.82	54.95	58.11	47.94	61.92	52.68
	AUG-2022	Leq	65.85	56.76	60.25	49.62	63.68	54.42
	SEP-2022	Leq	62.76	53.11	57.23	46.82	60.22	48.76
Norms		Industrial Area	75	70	75	70	75	70
Note: Noise Quality Monitoring done by MoEF approved 3rd Party M/s Vardan EnviroLab								

Annexure-7(B)

WORK PLACE NOISEQUALITY STATUS

Month			JULY-2022		SEPTEMBER-2022	
Parameters	Sr. No.	Location	Norms	Reading	Norms	Reading
Noise Level in dB (A)	1	TG-1-12 Mtr. Unit-1	85	72.64	85	70.38
	2	TG-1-6Mtr. Near MOT Unit -1	85	77.21	85	75.16
	3	BFP Unit-1	85	73.92	85	79.25
	4	TG -2 12Mtr- Unit-2	85	76.19	85	70.68
	5	TG-2 6 Mtr. Near MOT Unit -2	85	77.25	85	74.38
	6	BFP Unit -2	85	78.38	85	74.13
	7	Mill Area Unit -1	85	71.24	85	68.73
	8	Mill Area Unit -2	85	74.32	85	71.98
	9	ID Fan-2 Unit-2	85	75.32	85	76.54

Month			JULY-2022		SEPTEMBER-2022	
Parameters	Sr. No.	Location	Norms	Reading	Norms	Reading
Noise Level in dB (A)	10	ID Fan-I Unit-I	85	72.62	85	78.29
	11	FD Fan –I-Unit -I	85	70.44	85	72.11
	12	FD Fan –2-Unit -2	85	76.32	85	69.76
	13	DG Compressor Room	85	79.11	85	77.41
	14	AHP Compressor Room	85	80.24	85	79.32
	15	Boiler -1 12 Mtr APH	85	75.13	85	73.65
	16	Boiler -2 at 12 Mtr APH	85	70.63	85	71.83
	17	Chiller Area	85	66.92	85	76.48
Note: Workplace Noise Quality Monitoring done by MoEF approved 3rd Party M/s Vardan EnviroLab						

Month			JULY-2022		SEPTEMBER-2022	
Parameters	Sr. No.	Location	Norms	Reading	Norms	Reading
Noise Level in dB (A)	18	Wagon Tipper area	85	78.46	85	81.36
	19	Crusher Floor (3 rd Floor)	85	78.38	85	73.14
	20	Screen Floor(4 th Floor)	85	75.12	85	69.54
	21	DSS Pump House	85	61.26	85	71.28
	22	Ash Slurry Pump House	85	72.18	85	70.28
	23	LDO Pump House	85	74.82	85	67.48
	24	CW Pump House	85	79.22	85	73.46
	25	Fire Pump house	85	80.43	85	70.27
Note: Workplace Noise Quality Monitoring done by MoEF approved 3rd Party M/s Vardan EnviroLab						

Annexure – 8

AMBIENT AIR QUALITY STATUS

1.0 Location:- AAQMS Cabin-01 (Near VIP Gate)

Sr. No.	Parameters	Norms	TWA	Concentration					
				APRIL-22	MAY-22	JUNE-22	JULY-22	AUG-22	SEP-22
1.	Particulate Matter of size less than 2.5 µm (PM _{2.5}) µg/m ³	60	24 Hrs	29.47	25.49	30.71	27.86	25.24	27.44
2.	Particulate Matter of size less than 10 µm (PM ₁₀) µg/m ³	100	24 Hrs	58.12	52.25	60.15	60.42	61.0	64.10
3.	Nitrogen Dioxide (NO ₂) µg/m ³	80	24 Hrs	15.78	13.12	25.12	17.27	16.27	19.63
4.	Sulphur Dioxide (SO ₂) µg/m ³	80	24 Hrs	8.71	7.55	10.45	7.85	8.70	10.65
5.	Carbon Monoxide (CO) (mg/m ³)	2	8 Hrs	0.29	0.28	0.66	0.53	0.52	BLQ
6.	Ammonia (NH ₃) (µg/m ³)	400	24 Hrs	4.75	4.59	27.20	BLQ	BLQ	BLQ
7.	Benzene (C ₆ H ₆) (µg/m ³)	5	Annual	1.58	0.02	BLQ	BLQ	BLQ	BLQ
8.	Benzo(a) Pyrene (BaP) (ng/m ³)	1	Annual	0.51	1.24	BLQ	BLQ	BLQ	BLQ
9.	Ozone (O ₃) (µg/m ³)	100	24 Hrs	7.57	0.50	22.56	13.75	18.95	20.07
10.	Nickel (Ni) (ng/m ³)	20	Annual	5.90	7.23	BLQ	BLQ	BLQ	BLQ
11.	Lead (Pb) (µg/m ³)	1	24 Hrs	0.04	1.52	BLQ	BLQ	BLQ	BLQ
12.	Arsenic (As) (ng/m ³)	6	Annual	1.92	5.24	BLQ	BLQ	BLQ	BLQ

Note: All the above Ambient Air Quality Analysis were done by MOEF Approved 3rd party M/s Vardan EnviroLab

2.0 Location: - AAQMS Cabin-02 (Near ETP and RWH pond)

Sr. No.	Parameters	Norms	TWA	Concentration					
				APRIL-22	MAY-22	JUNE-22	JULY-22	AUG-22	SEP-22
1.	Particulate Matter of size less than 2.5 µm (PM _{2.5}) µg/m ³	60	24 Hrs	25.05	24.21	24.35	27.44	29.37	23.7
2.	Particulate Matter of size less than 10 µm (PM ₁₀) µg/m ³	100	24 Hrs	57.2	55.23	64.46	59.08	60.7	56.5
3.	Nitrogen Dioxide (NO ₂) µg/m ³	80	24 Hrs	17.24	14.25	27.35	17.99	18.35	16.82
4.	Sulphur Dioxide (SO ₂) µg/m ³	80	24 Hrs	8.29	7.96	11.61	9.42	9.19	8.62
5.	Carbon Monoxide (CO) (mg/m ³)	2	8 Hrs	0.33	0.34	0.68	0.58	0.58	BLQ
6.	Ammonia (NH ₃) (µg/m ³)	400	24 Hrs	3.81	3.86	31.43	BLQ	BLQ	BLQ
7.	Benzene (C ₆ H ₆) (µg/m ³)	5	Annual	1.43	1.11	BLQ	BLQ	BLQ	BLQ
8.	Benzo(a) Pyrene (BaP) (ng/m ³)	1	Annual	ND	ND	BLQ	BLQ	BLQ	BLQ
9.	Ozone (O ₃) (µg/m ³)	100	24 Hrs	5.85	5.56	25.89	14.53	20.9	25.64
10.	Nickel (Ni) (ng/m ³)	20	Annual	BLQ	BLQ	BLQ	BLQ	BLQ	BLQ
11.	Lead (Pb) (µg/m ³)	1	24 Hrs	0.04	0.03	BLQ	BLQ	BLQ	BLQ
12.	Arsenic (As) (ng/m ³)	6	Annual	2.08	1.42	BLQ	BLQ	BLQ	BLQ

Note: All the above Ambient Air Quality Analysis were done by MOEF Approved 3rd party M/s Vardan EnviroLab

3.0 Location: - AAQMS Cabin-03 (Near Old Switchyard)

Sr. No.	Parameters	Norms	TWA	Concentration					
				APRIL-22	MAY-22	JUNE-22	JULY-22	AUG-22	SEP-22
1.	Particulate Matter of size less than 2.5 µm (PM _{2.5}) µg/m ³	60	24 Hrs	26.78	25.34	32.37	29.10	29.36	30.35
2.	Particulate Matter of size less than 10 µm (PM ₁₀) µg/m ³	100	24 Hrs	61.45	56.36	57.69	64.59	65.50	58.01
3.	Nitrogen Dioxide (NO ₂) µg/m ³	80	24 Hrs	17.27	16.88	22.18	29.64	24.67	18.23
4.	Sulphur Dioxide (SO ₂) µg/m ³	80	24 Hrs	10.80	9.76	12.41	10.99	9.59	9.24
5.	Carbon Monoxide (CO) (mg/m ³)	2	8 Hrs	0.52	0.40	0.68	0.55	0.52	BLQ
6.	Ammonia (NH ₃) (µg/m ³)	400	24 Hrs	6.25	6.89	38.08	BLQ	BLQ	BLQ
7.	Benzene (C ₆ H ₆) (µg/m ³)	5	Annual	1.62	1.58	BLQ	BLQ	BLQ	BLQ
8.	Benzo(a) Pyrene (BaP) (ng/m ³)	1	Annual	ND	ND	BLQ	BLQ	BLQ	BLQ
9.	Ozone (O ₃) (µg/m ³)	100	24 Hrs	8.60	8.95	26.73	14.27	22.85	22.85
10.	Nickel (Ni) (ng/m ³)	20	Annual	5.46	5.24	BLQ	BLQ	BLQ	BLQ
11.	Lead (Pb) (µg/m ³)	1	24 Hrs	0.06	0.03	BLQ	BLQ	BLQ	BLQ
12.	Arsenic (As) (ng/m ³)	6	Annual	1.45	1.46	BLQ	BLQ	BLQ	BLQ

Note: All the above Ambient Air Quality Analysis were done by MOEF Approved 3rd party M/s Vardan EnviroLab

4.0 Location: - GET Hostel

Sr. No.	Parameters	Norms	TWA	Concentration					
				APRIL-22	MAY-22	JUNE-22	JULY-22	AUG-22	SEP-22
1.	Particulate Matter of size less than 2.5 µm (PM _{2.5}) µg/m ³	60	24 Hrs	24.13	22.20	28.03	24.95	25.23	25.36
2.	Particulate Matter of size less than 10 µm (PM ₁₀) µg/m ³	100	24 Hrs	50.45	45.68	62.47	55.84	56.24	61.00
3.	Nitrogen Dioxide (NO ₂) µg/m ³	80	24 Hrs	15.29	12.82	26.40	14.39	16.27	20.33
4.	Sulphur Dioxide (SO ₂) µg/m ³	80	24 Hrs	8.30	7.29	10.95	8.38	9.73	11.16
5.	Carbon Monoxide (CO) (mg/m ³)	2	8 Hrs	0.29	0.26	0.72	0.51	0.54	BLQ
6.	Ammonia (NH ₃) (µg/m ³)	400	24 Hrs	3.51	3.86	24.58	BLQ	BLQ	BLQ
7.	Benzene (C ₆ H ₆) (µg/m ³)	5	Annual	1.38	BDL	BLQ	BLQ	BLQ	BLQ
8.	Benzo(a) Pyrene (BaP) (ng/m ³)	1	Annual	BLQ	ND	BLQ	BLQ	BLQ	BLQ
9.	Ozone (O ₃) (µg/m ³)	100	24 Hrs	4.81	5.51	20.04	12.71	22.58	16.15
10.	Nickel (Ni) (ng/m ³)	20	Annual	BLQ	BDL	BLQ	BLQ	BLQ	BLQ
11.	Lead (Pb) (µg/m ³)	1	24 Hrs	0.03	0.02	BLQ	BLQ	BLQ	BLQ
12.	Arsenic (As) (ng/m ³)	6	Annual	1.79	1.21	BLQ	BLQ	BLQ	BLQ

Note: All the above Ambient Air Quality Analysis were done by MOEF Approved 3rd party M/s Vardan EnviroLab

5.0 Location: - Near Ash Pond

Sr. No.	Parameters	Norms	TWA	Concentration					
				APRIL-22	MAY-22	JUNE-22	JULY-22	AUG-22	SEP-22
1.	Particulate Matter of size less than 2.5 µm (PM _{2.5}) µg/m ³	60	24 Hrs	23.50	26.58	31.34	24.95	25.26	25.36
2.	Particulate Matter of size less than 10 µm (PM ₁₀) µg/m ³	100	24 Hrs	48.15	52.12	54.81	50.94	52.50	55.20
3.	Nitrogen Dioxide (NO ₂) µg/m ³	80	24 Hrs	12.32	13.44	24.26	13.67	14.86	17.53
4.	Sulphur Dioxide (SO ₂) µg/m ³	80	24 Hrs	7.46	8.59	9.83	7.85	8.19	7.61
5.	Carbon Monoxide (CO) (mg/m ³)	2	8 Hrs	0.23	0.38	0.73	0.54	0.57	BLQ
6.	Ammonia (NH ₃) (µg/m ³)	400	24 Hrs	5.29	BDL	31.23	BLQ	BLQ	BLQ
7.	Benzene (C ₆ H ₆) (µg/m ³)	5	Annual	BLQ	BDL	BLQ	BLQ	BLQ	BLQ
8.	Benzo(a) Pyrene (BaP) (ng/m ³)	1	Annual	BLQ	ND	BLQ	BLQ	BLQ	BLQ
9.	Ozone (O ₃) (µg/m ³)	100	24 Hrs	12.84	BDL	28.40	11.67	23.13	19.79
10.	Nickel (Ni) (ng/m ³)	20	Annual	2.56	2.12	BLQ	BLQ	BLQ	BLQ
11.	Lead (Pb) (µg/m ³)	1	24 Hrs	0.03	0.03	BLQ	BLQ	BLQ	BLQ
12.	Arsenic (As) (ng/m ³)	6	Annual	0.73	1.02	BLQ	BLQ	BLQ	BLQ

Note: All the above Ambient Air Quality Analysis were done by MOEF Approved 3rd party M/s Vardan EnviroLab

6.0 Location: - Mr. Maroti Shankar Roge house Village-Sonegaon

Sr. No.	Parameters	Norms	TWA	Concentration					
				APRIL-22	MAY-22	JUNE-22	JULY-22	AUG-22	SEP-22
1.	Particulate Matter of size less than 2.5 µm (PM _{2.5}) µg/m ³	60	24 Hrs	24.49	22.45	29.66	25.36	25.26	24.11
2.	Particulate Matter of size less than 10 µm (PM ₁₀) µg/m ³	100	24 Hrs	54.16	52.40	63.95	56.26	59.15	58.47
3.	Nitrogen Dioxide (NO ₂) µg/m ³	80	24 Hrs	14.87	14.88	23.91	15.11	18.40	20.33
4.	Sulphur Dioxide (SO ₂) µg/m ³	80	24 Hrs	7.77	7.37	10.53	9.42	9.73	8.12
5.	Carbon Monoxide (CO) (mg/m ³)	2	8 Hrs	0.38	0.31	0.66	0.52	0.57	BLQ
6.	Ammonia (NH ₃) (µg/m ³)	400	24 Hrs	BLQ	BLQ	28.0	BLQ	BLQ	BLQ
7.	Benzene (C ₆ H ₆) (µg/m ³)	5	Annual	ND	ND	BLQ	BLQ	BLQ	BLQ
8.	Benzo(a) Pyrene (BaP) (ng/m ³)	1	Annual	BLQ	BLQ	BLQ	BLQ	BLQ	BLQ
9.	Ozone (O ₃) (µg/m ³)	100	24 Hrs	7.22	5.16	21.16	13.49	23.97	16.16
10.	Nickel (Ni) (ng/m ³)	20	Annual	1.37	1.12	BLQ	BLQ	BLQ	BLQ
11.	Lead (Pb) (µg/m ³)	1	24 Hrs	0.03	0.03	BLQ	BLQ	BLQ	BLQ
12.	Arsenic (As) (ng/m ³)	6	Annual	1.83	1.48	BLQ	BLQ	BLQ	BLQ

Note: All the above Ambient Air Quality Analysis were done by MOEF Approved 3rd party M/s Vardan EnviroLab

7.0 Location: - Terrace of Shri Bapurao Pimpalkar House, Village - Wandhri

Sr. No.	Parameters	Norms	TWA	Concentration					
				APRIL-22	MAY-22	JUNE-22	JULY-22	AUG-22	SEP-22
1.	Particulate Matter of size less than 2.5 µm (PM _{2.5})µg/m ³	60	24 Hrs	24.31	22.33	23.81	26.19	25.38	26.61
2.	Particulate Matter of size less than 10 µm (PM ₁₀) µg/m ³	100	24 Hrs	52.43	48.09	59.06	55.0	53.7	62.69
3.	Nitrogen Dioxide (NO ₂) µg/m ³	80	24 Hrs	14.07	13.59	21.60	15.83	16.35	23.84
4.	Sulphur Dioxide (SO ₂) µg/m ³	80	24 Hrs	7.89	7.63	9.33	9.28	10.80	10.65
5.	Carbon Monoxide (CO) (mg/m ³)	2	8 Hrs	0.24	0.30	0.62	0.53	0.51	BLQ
6.	Ammonia (NH ₃) (µg/m ³)	400	24 Hrs	BLQ	BLQ	26.59	BLQ	BLQ	BLQ
7.	Benzene (C ₆ H ₆) (µg/m ³)	5	Annual	BLQ	BLQ	BLQ	BLQ	BLQ	BLQ
8.	Benzo(a) Pyrene (BaP) (ng/m ³)	1	Annual	ND	ND	BLQ	BLQ	BLQ	BLQ
9.	Ozone (O ₃) (µg/m ³)	100	24 Hrs	BLQ	BLQ	19.21	13.49	24.25	17.84
10.	Nickel (Ni) (ng/m ³)	20	Annual	1.74	1.86	BLQ	BLQ	BLQ	BLQ
11.	Lead (Pb) (µg/m ³)	1	24 Hrs	0.09	0.02	BLQ	BLQ	BLQ	BLQ
12.	Arsenic (As) (ng/m ³)	6	Annual	0.05	1.02	BLQ	BLQ	BLQ	BLQ

Note: All the above Ambient Air Quality Analysis were done by MOEF Approved 3rd party M/s Vardan EnviroLab

8.0 Location: - Terrace of Gram Panchayat, Village- Yerur

Sr. No.	Parameters	Norms	TWA	Concentration					
				APRIL-22	MAY-22	JUNE-22	JULY-22	AUG-22	SEP-22
1.	Particulate Matter of size less than 2.5 µm (PM _{2.5}) µg/m ³	60	24 Hrs	22.52	25.36	29.46	20.79	20.99	24.53
2.	Particulate Matter of size less than 10 µm (PM ₁₀) µg/m ³	100	24 Hrs	42.36	48.1	60.14	45.19	48.41	59.38
3.	Nitrogen Dioxide (NO ₂) µg/m ³	80	24 Hrs	16.31	15.04	26.14	16.5	15.54	21.73
4.	Sulphur Dioxide (SO ₂) µg/m ³	80	24 Hrs	7.06	7.91	8.14	8.90	7.67	8.62
5.	Carbon Monoxide (CO) (mg/m ³)	2	8 Hrs	0.37	0.32	0.67	0.53	0.51	BLQ
6.	Ammonia (NH ₃) (µg/m ³)	400	24 Hrs	4.68	3.51	25.79	BLQ	BLQ	BLQ
7.	Benzene (C ₆ H ₆) (µg/m ³)	5	Annual	BLQ	BLQ	BLQ	BLQ	BLQ	BLQ
8.	Benzo(a) Pyrene (BaP) (ng/m ³)	1	Annual	0.59	ND	BLQ	BLQ	BLQ	BLQ
9.	Ozone (O ₃) (µg/m ³)	100	24 Hrs	5.85	5.85	21.99	12.71	23.97	26.20
10.	Nickel (Ni) (ng/m ³)	20	Annual	1.75	1.88	BLQ	BLQ	BLQ	BLQ
11.	Lead (Pb) (µg/m ³)	1	24 Hrs	0.03	0.02	BLQ	BLQ	BLQ	BLQ
12.	Arsenic (As) (ng/m ³)	6	Annual	1.08	1.24	BLQ	BLQ	BLQ	BLQ

Note: All the above Ambient Air Quality Analysis were done by MOEF Approved 3rd party M/s Vardan EnviroLab

Annexure-9

DHARIWAL INFRASTRUCTURE LIMITED,

Tadali, Dist. Chandrapur

Six Months (April 2022 To September 2022)

**Consolidated Report on
Corporate Social Responsibility**

Year 2022-2023

Broad CSR Initiatives

- 1) Education Program
- 2) SHG Program
- 3) Agriculture Program
- 4) Sanitation Program
- 5) Adolescence girls Program
- 6) Skill development Program

Education Program

Objective:

To provide access to quality education to 390 children from 6- 14 years of age and develop their overall persona through extracurricular activities.

Activity :

- Organized 6 monthly Balsakhi meeting for collect the monthly compile report of the 9 villages.
- Organized summer camp at 9 villages. 641 Students were participated.
- Organized meeting with GP Members of 9 villages, 14 GP members were participated.
- Organized parents meeting at 9 villages, 379 parents were participated.
- Organized Pustakwala program at 9 villages , 209 students were benefitted.
- Organized General knowledge exam at 9 villages, 370 students were participated.
- Started English Spoken English Classes in Morwa and Shengaon , 67 Students were benefitted in both villages .
- Organized Career Guidance Program in collaboration with District Govt. 89 students were benefitted.
- Organized book bank rally program in 9 villages, 235 students were participated as well as benefitted.
- Organized Drawing competition in Morwa 9 villages students , 250 students were participated.
- Organized Navaratri Festival in 9 villages.
- Organized School management committee & Sarpanch meet at 9 villages.
- Organized 3 Balsakha workshop on mathematics, Language and English for the Balsakhi (teacher) .

Output:

- 50 % Syllabus covered till September.
- DIL got Best Education award from district govt.
- Students utilized their free time in summer camp activities.
- Students actively participated in task activity & expressed their talent on programs.
- Parents & SMC members actively involved in education program.
- 34 Balsakhi & volunteers got appreciation certificate from District Govt. for conducting free coaching classes in 9 village.



Balsakhi Monthly Meeting



Summer Camp Activity



GP Members Meeting



Parents Meet



Pustakwala Program



Career Guidance Session



Chavadi Vachan & Book Bank Rally



Balsakha Workshop



Akarbhint Program



Drawing Competition



Best Education award from Gov.



Shikshandan Appreciation Certificate



GK Competition (EXAM)



L2R Class



Shikshandan certificate Distribution



Drawing Competition (Prize distribution)



Education Library



Balsakha Workshop



Parents Meeting



Drawing competition



Mazi Kamai

SHG Program

Objective:

Motivating & enabling 100 women for self-employment through SHG and providing them capital to set up Micro enterprises.

Activities:

- Conducted 6 monthly business data collection meeting.
- Conducted meeting with RCT, Panchayat samiti, NABARD for self-employment training program.
- Participated in Udyamita Training (Central Govt. Self-employment guidance program for SHG). 150 SHG members were benefitted.
- Exposure visit at **MGIRI, Wardha & Gokul Kuti Udyog, Hinganghat** for learning new technique of micro enterprises for SHG groups.
- Organized Navratri festival in 9 villages. 57 were participated.
- Organized 2 days pickle & Papad training program in Morwa. 40 SHG members were benefitted.
- Conducted meeting with every month in 9 villages.
- Survey in Yerur and Sonegaon for new group formation and 1 group formed in Sonegaon.

Output:

- 20 SHG members start Pickle & Achar business & got the source of income in village level.
- 60 SHG members are ready to take for LED bulb making training.
- 40 SHG members took pickle & Papad training and another 40 SHG members are ready to take same training will organize in Yerur village.



SHG Meeting



Udyamita Training



Udyamita Training



Solar Equipment Trainer Visit



Exposure Visit MGIRI, Wardha



Wardini Kendra, Wardha



Durga Mandal Visit Yerur



Navratri Festival



Achar Papad Training Morva



Poultry farm



Achar Papad Training Morva



Achar Papad Training Tadali

Agriculture Program

Objective:

To promote and strengthen efficient and effective management of agricultural production and productivity through management of farms in order to ensure economic and environmental sustainability of farmers.

Activity:

- Organized farmers club meeting at 9 villages, 268 farmers were participated.
- 2 farmer Club formation in Soneagon .
- Submit agriculture proposal to Nabard for exposure visit.
- Visit in KVK Sindewahi for Reservoir agriculture project.
- Conducted meeting with collector for reservoir agriculture project with KVK scientist.
- Conducted meeting with District Agriculture Officer for reservoir agriculture project.
- Inform the farmer about the crop insurance scheme of Govt.
- 1500 Nos. fruits saplings were distributed to 9 villages.

Output:

- Farmers got information about the government scheme, 176 farmers applied for the scheme.
- Farmers got the information about the seed selection before cultivation.
- Will start agriculture project with coloration with NABARD.



Plant Distribution at Tadali



Plant Distribution at Yerur



Plant Distribution at Morva

Health & Sanitation Program

Objective:

To bring about an improvement in the general quality of life in the rural areas by motivating the communities and Panchayati Raj Institutions through awareness creation and health education.

Activity:

- Organized 5 health checkup camp in 5 villages (Wadha , Dhanora ,Sonegaon , Mowa & Anturla) . 564 Villagers were benefitted also medicine distributed.
- Organized post vaccination camp at DIL, 150 villagers vaccinated.
- Organized eye checkup camp at Sonegaon. 183 villagers were benefitted as well as 50 spectacles were distributed.
- Organized meeting for the youth club formation, 60 youths were participated.
- Organized meeting with Gram panchayat members to discuss about health & sanitation.
- Install high mask in Pandharkawada village
- Home to home awareness has been done in villages on health and sanitation.

Output:

- 183 villagers of Sonegaon took the benefit of the eye check-up camp.
- 564 villagers got free medical treatment in dearth.
- 150 Villagers were got booster dose.
- 20 villagers were ready to construct toilets in their home



Health Checkup Camp, Anturla



Health Checkup Camp,Sonegaon



Eye Checkup Camp,Sonegaon

Adolescence girls Program

Objective:

300 adolescent girls to enable for self-development and empowerment, to improve their nutrition and health status, promote awareness about health, menstrual hygiene, nutrition, sexual health, & upgrade home-based skills, vocational & life skill.

Activity:

- Organized monthly and weekly meeting for the adolescence girls, to discuss their problems.
- Organized carrier guidance session and goal setting session 35 adolescence girls were participated.
- Organized 2 Session on menstrual hygiene in Pandharkawda . 70 adolescence girls were participated.
- Organized Navratri festival in 9 villages. 110 adolescent's girls were benefitted.
- Organized session on Child psychology, 63 adolescence girls were participated.
- Organized meeting with PHC center, Gram Panchayat and School .
- Organized historical study tours at Manikgh, 11 adolescence girls were participated.
- Organized HB camp in five villages (Morva ,Sonegaon,Shengaon , Anturla & Pandharkawda). 252 adolescence girls were benefitted.
- Organized Heath camp on skin related by dermatologist in Yerur villages . 75 girls were benefitted.

Output:

- 88 adolescence girls HB level found bellow 8.5 gm. They got medicine & guidance on nutrition and diet under the supervision of medical officer.
- Adolescence girls got free treatment on skin and routine illness.
- Adolescence girls aware about the menstrual hygiene problem.
- Due to Navratri festival girls confidence were increased.
- Due to carrier guidance program most of the girls are choosing their field as per their interest .



Durga Mandal Meeting Shenagon



Navratri Festival Anturla



Navratri Festival Morva



HB camp Sonegaonv



HB camp Anturla




Navratri Final Inauguration



Workshop on Child psychology



Dermatology Awareness Camp



Adolescent Girls Weekly Meeting

Skill Development program

Objective:

To support village youth in attaining technical skill to be gainfully, economic empowerment of youths from underprivileged community.

Activity:

- 2 youths were admitted for mobile repairing center .
- Meeting with grampanchayat for skill training.
- Meeting with Youth for skill training . 156 youth were participated
- Inauguration of mobile repairing center.

Output:

- 2 youth started mobile repairing center at Sonegaon & Tadli and got source of income.



Mobile Repairing Training



**Cheque Donate Grampanchayt
Tadali**



**Cheque Donate
Grampanchayt Wadha**

O/c



**RP-Sanjiv Goenka
Group**
Growing Legacies



Dhariwal Infrastructure Limited

CIN : U70109WB2006PLC111457
E-mail : dhariwalinfrastructure@rpsg.in

Ref: DIL/HSE/F-08/22-23/56

Date : 21.09.2022

To,
The Member Secretary,
Maharashtra Pollution Control Board;
Kalpataru Point, 3rd Floor,
Sion Matunga Road No.8,
Sion East,
Mumbai-400022.

**Sub: Submission of Environmental Statement for the financial year ending 31st
March 2022.**

Dear Sir,

We have submitted online, the Annual Environment Statement for the financial year 2021-22 on EC MPCB Portal. Copy of the Environment Statement (Form-V) downloaded from EC MPCB portal along with annexures is attached herewith for your ready reference.

We hope you will find the same in order.

Thanking you,

Yours Faithfully,
For Dhariwal Infrastructure Limited.

Authorized Signatory

CC:

1. The Regional Officer,
Maharashtra Pollution Control Board,
1st Floor, Udyog Bhawan,
Chandrapur (Maharashtra).

22-09-2022
Maharashtra Pollution Control Board
Regional office
Udyog Bhawan 1st Floor Station Road,
Chandrapur-442401.